

ARTICLE 6. WATER UTILITIES

Rule 1. Standards of Service

170 IAC 6-1-1 Definitions

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-1

Sec. 1. Definitions. (A) Where applicable, the definitions set forth in IC 8-1-2-1 (Burns 54-105) shall be applied to these rules, and

(B) The word “customer” shall mean any person, firm, corporation, municipality or other government agency which has agreed, orally, or otherwise, to pay for water service received from a water utility; provided, that for the purposes of Rules 15, 16 and 16.1 [170 IAC 6-1-15–170 IAC 6-1-17], the word “customer” shall be limited to mean persons who have agreed to pay for such service exclusively for residential purposes.

(C) The word “disconnection” shall mean the termination or discontinuance of water service.

(D) The words “late payment charge” shall mean the one time penalty assessed by a water utility upon all current bills at such time as they become delinquent.

(E) The word “commission” shall mean the Public Service Commission of Indiana. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 1; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 678; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-2 Applicability of rules

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2

Sec. 2. Application of Rules. These rules [170 IAC 6-1] shall apply to any public water utility subject to the jurisdiction of the commission pursuant to the provisions of the Public Service Commission Act [IC 8-1-2], or any other statute of the State of Indiana, which is now or hereafter may be engaged in the production, sale or distribution of water service (herein called “utility” or “water utility.”) (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 2; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 679; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-3 Retention of records

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-12; IC 8-1-2-40

Sec. 3. Records to be Kept. All records required by these rules [170 IAC 6-1] shall be preserved for at least three years except as otherwise provided herein or by IC 8-1-2-40 (Burns 54-135). Such records shall be kept within the State at the principal place of business of the water utility, or at such other places within the State as the utility shall designate after notification to the commission, and shall be open for examination by the commission or its representatives. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 3; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 679; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-4 Meter records and reports

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-12; IC 8-1-2-34; IC 8-1-2-35

Sec. 4. Record of Meters and Meter Tests. (A) Meter Test Record. Whenever any meter in service is tested, a record shall be preserved containing the information necessary for identifying the meter, the reason for making the test, the reading of the meter before the test and the result of the test, together with all data taken at the time of the test in sufficiently complete form to permit the convenient checking of the methods employed.

(B) Meter Record. Permanent records shall also be kept, systematically arranged, giving for each meter owned or used by any water utility, the year of purchase, its identification and the record of the last test to which it has been subjected, with dates and general results of the test. These requirements apply to all meters purchased after the effective date of these rules and to all other

meters insofar as the information is available.

(C) Tabulation of Meter Tests. If required by the commission, annual tabulations of the results of all meter tests shall be made, arranged according to types and sizes of meters and intervals of tests or as the commission may request. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 4; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 679; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-5 Location of meters

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-34; IC 8-1-2-35

Sec. 5. Location of Meters. The meter may be located either in an outdoor pit, or inside the building or premises of the customer being served.

When the meter is to be installed in an underground pit, the pit shall be located in a convenient and readily accessible location. Upon request by the customer before the installation is made, the pit will be located at the point requested, if feasible under proper utility standards. The pit must be constructed to protect the meter from freezing and damage by vehicular traffic. The pit location and design should prevent, as far as possible, the inflow of surface water.

When the meter is to be installed indoors, it shall be located, as near as practical to where the service pipe enters the building, in a clean, dry, safe place, protected from freezing and hot water, not subject to wide temperature variations, and so placed as to be at all times accessible for reading, inspection and removal for testing.

If a customer requests and the utility approves, or if the utility determines that it is desirable in order to facilitate meter reading, a remote reading register device may be installed outside the building at an accessible location. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 5; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 679; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-6 Meter dials

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-32; IC 8-1-2-33; IC 8-1-2-34

Sec. 6. Meter Dials. All meters used to measure the volume of water sales shall register in either U.S. gallons, cubic feet, or metric units. The meter register face shall clearly indicate whether the register is in U.S. gallons, cubic feet, or metric units. Straight and circular reading registers shall have printed on the dial face the required numerals, so that the meter can be correctly read to the nearest 100 cubic feet, 1,000 U.S. gallons, or the metric equivalent thereof. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 6; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 680; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-7 Testing equipment and facilities; portable test meters

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-34; IC 8-1-2-35; IC 8-1-2-36

Sec. 7. Testing Equipment and Facilities. (A) Equipment. Each water utility furnishing water to any of its customers on a metered basis shall provide and maintain suitable equipment and facilities for testing and adjusting its meters satisfactory to the Commission. Meter testing equipment shall at all reasonable hours be accessible for inspection and use by authorized representatives of the Engineering Department of the Commission. Upon written request, the Engineering Department of the Commission may exempt a utility from this requirement if satisfactory arrangements are made for the testing and adjusting of its meters by another water utility or repair agency, equipped to test meters properly in compliance with the Commission's rules and regulations.

(B) Portable Test Meters. Where portable test meters are used to determine the accuracy of meters in service, they shall be recalibrated by suitable testing apparatus at sufficiently frequent intervals to insure correct registration at the specified rates of flow. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 7; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 680; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-8 Accuracy of meters

Authority: IC 8-1-1-3; IC 8-1-2-4
 Affected: IC 8-1-2-35

Sec. 8. Meter Accuracy. (A) General. All meters and appurtenances used for measuring quantity of water delivered to a customer shall be in good mechanical condition and shall be adequate in size and design for the type of service which they measure and shall be accurate to within generally accepted standards.

(B) Test Flows. For determination of minimum test flow and normal test flow limits, the following specifications will be used for test flows for displacement type cold water meters:

Nominal Meter Size	Minimum Test Flow Gallons Per Minutes	Normal Test Flow Limit Gallons Per Minute
5/8"	1/4	1-20
3/4"	1/2	2-30
1"	3/4	3-50
1 1/2"	1 1/2	5-100
2"	2	8-160
3"	4	16-300
4"	7	28-500
6"	12	48-1000

(Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 8; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 680; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1-9 Determination of meter accuracy

Authority: IC 8-1-1-3; IC 8-1-2-4
 Affected: IC 8-1-2-35

Sec. 9. Determination of Accuracy. Displacement meters shall be tested at three or more test flows: One at the minimum test flow, one at not more than 10% of the maximum normal test flow limit, and one not less than 35% of the maximum normal test flow limit. A meter shall not be placed in service if it registers less than 95% of the water passed through it at the minimum test flow or over or under registers more than 1 1/2% in the normal test flow limits, with the exception that a repaired meter shall register not less than the following appropriate percentage of the water passed through it at the minimum test flow, and shall not over or under register more than 2% in the normal test flow limits.

If manufactured on or after January 1, 1955 90%
 If manufactured prior to January 1, 1955 85%

(Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 9; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 681; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1-10 Periodic inspections and tests

Authority: IC 8-1-1-3; IC 8-1-2-4
 Affected: IC 8-1-2-35

Sec. 10. Periodic Tests. (A) For testing the accuracy of water meters, the utility may either adopt one of the methods set out in Rule 10(B) and 10(C) [subsections (B) and (C) of this section], or request approval of an alternative method, as provided for in Rule 10(D) [subsection (D) of this section].

(B) Each consumer water meter installed shall be periodically inspected and tested in accordance with the following schedule, or more often if the results may warrant, to insure that the meter accuracy is maintained within the limits set out in Rule 9 [170 IAC 6-1-9].

5/8-inch meters	-10 years, or for 100,000 cubic feet or equivalent units registered
3/4-inch meters	-8 years, or for each 150,000 cubic feet or equivalent units registered
1-inch meters	-6 years, or for each 300,000 cubic feet or equivalent units registered
1 1/2-inch and over	-4 years

(C) The schedule of periodic testing for installed water meters set forth above in Rule 10(B) [subsection (B) of this section] may be extended by the use of the following Statistical Quality Control Program:

(1) The Statistical Quality Control Program shall be based on Military Standard No. 105-D, Sampling Procedures and Tables for Inspection by Attributes. Sample size code letters shall be taken from Table I, General Inspection Level II. Sample size and acceptance-rejection numbers shall then be determined from Table II A, single sampling plan for normal inspection, using Acceptance Quality Level (AQL) 10.

(2) The meters for quality control sampling shall be separated into homogeneous groups by manufacture, model, design, or other distinguishing characteristics by year set. The sample for each group shall, as far as possible, be taken from routine meter exchanges, removals, and field tests for each year, except that those meters removed or exchanged because of known or suspected defects or for special tests may be excluded from the quality control sample.

(3) If an inadequate sample of meters is routinely exchanged or removed, the balance of meters required for sampling will be obtained from meters in service by removal on a randomly selected basis.

(4) Beginning in the year prior to the last year indicated in the schedule of periodic testing set forth in Rule 10(B) [subsection (B) of this section], and continuing through subsequent service years, meter groups shall be sample tested annually, being allowed to continue in service until an annual sample reaches its rejection number of deviant meters. The service life of meter groups may be extended by this quality control program as long as ninety percent of the meters in a sample group do not exceed an accuracy figure of 102.0 percent when tested at not less than 35% of its rated capacity.

(D) If any utility can furnish evidence that the methods outlined in Rule 10(B) and 10(C) [subsections (B) and (C) of this section] are not necessary, an alternate testing method may be used if submitted to and approved by the Engineering Department of the Commission. (Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 10; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 681; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1-11 Customer request for meter test; application to utility

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-35

Sec. 11. Meter Tests Upon Written Request by Customer to Utility. Each utility supplying water service shall make a test of the accuracy of registration of a meter upon written request by a customer. A second test of the customer's meter may be requested after twelve (12) months. The customer may be required to bear the full cost of any subsequent test of his meter if requested at less than thirty-six (36) months after the preceding test, if error of the meter is found to be in compliance with Rule 9 [170 IAC 6-1-9]. A written report giving the results of such tests shall be made to the customer within 10 days after the test is complete and a complete record of the same shall be kept on file in the office of the utility. Any appeal, in regard to the results of the customer's meter test, shall be filed with the Commission under Rule 12 [170 IAC 6-1-12] within five (5) days of the date of the report. (Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 11; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 682; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1-12 Customer request for meter test; application to public service commission

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-35

Sec. 12. Meter Tests Upon Application to the Commission. (A) A test will be made of a customer's meter by the utility under the supervision of an employee of the Commission upon application to the Commission by the customer and formal notice to the utility by the Commission. The application for such a test shall be accompanied by a fee as set out below in paragraph (B). This fee paid by the customer shall be retained by the Commission; however, if the tests show the meter to be more than two per cent (2%) fast, the utility supplying the water service shall reimburse the customer the amount of such fee.

(B) The amount of fee to be paid for a meter test made on application to the Commission shall be as follows:

Through 3/4" meter	\$ 8.00
1" meter through 2" meter	\$16.00
Above 2" meter	Actual cost of test

(C) This rule [this section] shall not interfere with the practice of a utility in its tests of water service meters except that, in the event of a written application to the Commission by a customer for a test, the utility shall not knowingly remove or interfere with

said meter without the consent previously given in writing by the customer. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 12; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 682; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-13 Bills

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2

Sec. 13. Bills for Water Service. (A) Bills rendered periodically to customers for water service shall show at least the following information:

- (1) The dates and meter readings of the meter at the beginning and end of the period for which the bill is rendered and the billing date,
- (2) The number and kind of units of service supplied,
- (3) The billing rate code, if any,
- (4) The previous balance, if any,
- (5) The amount of the bill,
- (6) The sum of the amount of the bill and the late payment charge, if any,
- (7) The date on which the bill becomes delinquent and on which a late payment charge will be added to the bill,
- (8) If an estimated bill, a clear and conspicuous coding or other indication identifying the bill as an estimated bill,
- (9) Printed statements and/or actual figures on either side of the bill shall inform the customer of the seventeen (17) day non-penalty period.
- (10) An explanation, which can be readily understood, of all codes and/or symbols shall be shown on the bill.

(B) Delinquencies. (1) A utility service bill which has remained unpaid for a period of more than seventeen (17) days following the mailing of the bill shall be a delinquent bill.

(2) A utility service bill shall be rendered as a net bill. If the net bill is not paid within seventeen (17) days after the bill is mailed, it shall become a delinquent bill and a late payment charge may be added in the amount of ten (10) percent of the first three (3) dollars and three (3) percent of the excess of three (3) dollars.

(C) Estimated Billing. A water utility may estimate the bill of any customer pursuant to a billing procedure approved by the Commission or for other good cause, including, but not limited to: request of customer; inclement weather; labor or union disputes; inaccessibility of a customer's meter if the utility has made a reasonable attempt to read it; and other circumstances beyond the control of the utility, its agents and employees. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 13; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 683; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-14 Billing adjustments

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-34

Sec. 14. Adjustment of Bills. (A) Adjustments Due to Meter Error. If any service meter shall be found to have a percentage of error greater than that allowed in Rule 9 [170 IAC 6-1-9], the following provisions for the adjustment of bills shall be observed:

(1) Fast Meters. When a meter is found to have a positive average error, i.e., is fast, in excess of two (2) percent, the utility shall refund or credit the customer's account with the amount in excess of that determined to be an average charge for one-half of the time elapsed since the previous test, or one (1) year, whichever period is shorter. This average charge shall be calculated on the basis of units registered on the meter over corresponding periods either prior or subsequent to the period for which the meter is determined to be fast. No part of a minimum service charge need be refunded.

(2) Stopped or Slow Meters. When a meter is stopped or has a negative average error, i.e., is slow, in excess of two (2) percent, the utility may charge the customer an amount estimated to be an average charge for one-half of the time elapsed since the previous test or one (1) year, whichever period is shorter. This average charge shall be calculated on the basis of units registered on the meter over corresponding periods either prior or subsequent to the period for which the meter is determined to be slow or stopped. Such action may be taken only in cases where the utility is not at fault for allowing the stopped or slow meter to remain in service.

(B) Adjustment for Interruption of Service. In the event the customer's service is interrupted for a reason other than the act of

the customer or the condition of customer controlled equipment, and the service remains interrupted for more than two (2) days after being reported or found to be out of order, appropriate adjustments or refunds shall be made to the customer. Each company shall file with the commission a tariff detailing the method and amount of refund in such cases.

(C) Other Billing Adjustments. All other billing errors, including incorrect tariff applications, may be adjusted to the known date of error or for a period of one year, whichever period is shorter. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 14; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 684; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-15 Creditworthiness of customer; deposit; refund

Authority: IC 8-1-1-3

Affected: IC 8-1-2; IC 32-34-1-20

Sec. 15. (a) Each utility shall determine the creditworthiness of residential applicants or customers in an equitable and nondiscriminatory method:

- (1) without regard to the economic character of the area wherein the applicant or customer resides; and
- (2) solely upon the credit risk of the individual without regard to the collective credit reputation of the area in which he or she lives.

(b) Each new applicant for residential water service shall be deemed creditworthy and shall not be required to make a cash deposit as a condition of receiving service if the applicant satisfies the following criteria:

- (1) If the applicant has been a customer of any utility within the last two (2) years, the applicant:
 - (A) owes no outstanding bills for service rendered within the past four (4) years by any such utility;
 - (B) during the last twelve (12) consecutive months that the service was provided, did not have more than two (2) bills that were delinquent to any utility or, if service was rendered for a period for less than twelve (12) months, did not have more than one (1) delinquent bill in such period; and
 - (C) within the last two (2) years did not have a service disconnected by a utility for nonpayment of a bill for services rendered by that utility.

(2) If the applicant has not been a customer of a utility during the previous two (2) years, any two (2) of the following criteria are met:

- (A) The applicant either:
 - (i) has been employed by his or her present employer for two (2) years;
 - (ii) has been employed by his or her present employer for less than two (2) years, but has been employed by only one (1) other employer during the past two (2) years; or
 - (iii) has been employed by the present employer for less than two (2) years and has no previous employment due to recently:
 - (AA) graduating from a school, university, or vocational program; or
 - (BB) being discharged from military service.

- (B) The applicant either:
 - (i) owns or is buying his or her home; or
 - (ii) is renting a home or an apartment and has occupied the premises for more than two (2) years.

(C) The applicant has credit cards, charge accounts, or has been extended credit by a bank or commercial concern unless a credit check shows that the applicant has been in default on any such account more than twice within the last twelve (12) months.

(c) If the applicant fails to establish that he or she is creditworthy, under subsection (b), the applicant may be required to make a reasonable cash deposit. Such deposit shall not exceed one-sixth ($\frac{1}{6}$) of the estimated annual cost of service to be rendered to the applicant. If a deposit is greater than seventy dollars (\$70), the utility shall advise the applicant or customer simultaneously with making a demand for a deposit that the applicant or customer may pay such deposit in equal installment payments over a period of no less than eight (8) weeks; service shall be connected upon receipt by the utility of the first such payment.

(d) If the utility requires a cash deposit as a condition of providing service, then it must immediately notify the applicant in writing stating the precise facts upon which the utility based its decision and provide the applicant with an opportunity to rebut such facts and show other facts demonstrating his or her creditworthiness.

(e) A utility may require a present customer to make a reasonable cash deposit when:

WATER UTILITIES

- (1) the customer has been mailed disconnect notices for two (2) consecutive months;
- (2) the customer has been mailed disconnect notices for any three (3) months within the preceding twelve (12) month period;
- or
- (3) the service to the customer has been disconnected within the past four (4) years pursuant to section 16 of this rule.

The amount of such deposit may not exceed an amount equal to one-sixth ($\frac{1}{6}$) of the expected annual billings for the customer at the address at which service is rendered. In the event the required deposit is in excess of seventy dollars (\$70), the utility shall advise the customer that he or she may pay such deposit in equal installment payments over a period of up to eight (8) weeks, except where such deposit is required as a result of a disconnection for nonpayment, in which case full payment of the deposit may be required prior to reconnection.

(f) Requirements for interest upon deposits shall be as follows:

- (1) Deposits held more than twelve (12) months shall earn interest from the date of deposit at a rate of six percent (6%) per annum or at such other rate of interest as the commission may prescribe following a public hearing.
- (2) The deposit shall not earn interest after the date it is mailed or personally delivered to the customer, or otherwise lawfully disposed.

(g) Requirements for refunds shall be as follows:

(1) Any deposit or accrued interest shall be promptly refunded to the customer without the customer's request when the customer:

(A) submits satisfactory payment for a period of either:

(i) nine (9) successive months; or

(ii) ten (10) out of any twelve (12) consecutive months without late payment in two (2) consecutive months; or

(B) demonstrates his or her creditworthiness as provided by subsection (b).

(2) Refunds of deposits or accrued interest issued under this section must be accompanied by a statement of accounting for each transaction affecting the deposit and interest.

(3) Following customer-requested termination of service, the utility shall:

(A) apply the deposit, plus accrued interest, to the final bill; or

(B) upon specific request from the customer, refund the deposit, plus accrued interest, within fifteen (15) days after payment of the final bill.

(4) Each utility shall maintain a record of each applicant or customer making a deposit that shows the following:

(A) The name of the customer.

(B) The current address of the customer so long as he or she maintains an active account with the utility in his or her name.

(C) The amount of the deposit.

(D) The date the deposit was made.

(E) A record of each transaction affecting such deposit.

(5) Each customer shall be provided a written receipt from the utility at the time his or her deposit is paid in full or when he or she makes a cash partial payment. The utility shall provide a reasonable method by which a customer who is unable to locate his or her receipt may establish that he or she is entitled to a refund of the deposit and payment of interest thereon.

(6) Any deposit made by the applicant, customer, or any other person to the utility (less any lawful deductions), or any sum the utility is ordered to refund for utility service, that has remained unclaimed for one (1) year after the utility has made diligent efforts to locate the person who made such deposit or the heirs of such person, shall be presumed abandoned and treated in accordance with IC 32-9-1.5-20(c)(10) [*IC 32-9 was repealed by P.L.2-2002, SECTION 128, effective July 1, 2002.*].

(7) A deposit may be used by the utility to cover any unpaid balance following disconnection of service under section 16 of this rule; provided, however, that any surplus be returned to the customer as provided in subsection (f) and this subsection.

(Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 15; filed Nov 28, 1977, 3:00 p.m.: Rules and Regs. 1978, p. 684; filed Oct 28, 1998, 3:22 p.m.: 22 IR 732; errata filed Nov 22, 1999, 3:31 p.m.: 23 IR 812; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1-16 Disconnection of service; prohibited disconnection; reconnection

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-4; IC 8-1-2-113

WATER UTILITIES

Sec. 16. Disconnection of Service. (A) Upon Customer's Request. (1) The customer shall notify the utility at least three (3) days in advance of the day disconnection is desired. The customer shall remain responsible for all service used and the billings therefor until service is disconnected pursuant to such notice.

(2) Upon request by a customer of a utility to disconnect service, the utility shall disconnect the service within three (3) working days of the requested disconnection date. The customer shall not be liable for any service rendered to such address or location after the expiration of these three (3) days.

(B) Without Customer's Request. (1) A utility may disconnect service without request by the customer and without prior notice only:

- (a) if a condition dangerous or hazardous to life, physical safety or property exists; or
- (b) upon order by any court, the Commission or other duly authorized public authority; or
- (c) if fraudulent or unauthorized use of water is detected and the utility has reasonable ground to believe the affected customer is responsible for such use; or
- (d) if the utility's regulating or measuring equipment has been tampered with and the utility has reasonable grounds to believe that the affected customer is responsible for such tampering.

(2) In all other instances a utility, upon providing the customer with proper notice (as defined in Rule 16 (E) [subsection (E) of this section]), may disconnect service subject to the other provisions of these rules.

(C) Prohibited Disconnection. (1) Except as otherwise provided in subsection 16 (A) and 16 (B) [subsections (A) and (B) of this section], a utility shall postpone the disconnection of service for ten (10) days if, prior to the disconnect date specified in the disconnect notice, the customer provides the utility with a medical statement from a licensed physician or public health official which states that disconnection would be a serious and immediate threat to the health or safety of a designated person in the household of the customer. The postponement of disconnection shall be continued for one additional ten (10) day period upon the provision of an additional such medical statement.

(2) A utility may not disconnect service to the customer:

- (a) upon his failure to pay for merchandise or appliances purchased from the utility furnishing the water;
- (b) upon his failure to pay for the service rendered at a different metering point, residence, or location if such bill has remained unpaid for less than forty-five (45) days;
- (c) upon his failure to pay for services to a previous occupant of premises to be served, unless the utility has good reason to believe the customer is attempting to defraud the utility by using another name;
- (d) upon his failure to pay for a different form or class of utility service; or
- (e) if the customer shows cause for his inability to pay the full amount due (financial hardship shall constitute cause), and said customer:
 - (i) pays a reasonable portion (not to exceed \$10 or one tenth (1/10) of the bill, whichever is less, unless the customer agrees to a greater portion) of the bill; and
 - (ii) agrees to pay the remainder of the outstanding bill within three (3) months; and
 - (iii) agrees to pay all undisputed future bills for service as they become due; and
 - (iv) has not breached any similar agreement with the utility made pursuant to this rule within the past twelve months.

Provided, however, that the utility may add to the outstanding bill a late payment charge not to exceed the amount set pursuant to Rule 13 (B) [170 IAC 6-1-13(B)]. Provided further, that the above terms of the agreement shall be put in writing by the utility and signed by the customer and by a representative of the utility. Only one late payment charge may be made to the customer under this section.

(f) If a customer is unable to pay a bill, which is unusually large due to prior incorrect reading of the meter, incorrect application of the rate schedule, incorrect connection or functioning of the meter, prior estimates where no actual reading was taken for over two months, stopped or slow meter, or any human or mechanical error of the utility, and the customer:

- (i) pays a reasonable portion of the bill, not to exceed an amount equal to the customer's average bill for the twelve (12) bills immediately preceding the bill in question; and,
- (ii) agrees to pay the remainder at a reasonable rate, and
- (iii) agrees to pay all undisputed future bills for service as they become due;

Provided, however, that the utility may not add to the outstanding bill any late fee. Provided, further, that the above terms of agreement shall be put in writing by the utility and signed by the customer and a representative of the utility.

WATER UTILITIES

(3) If a customer proceeds with a review pursuant to Rule 16.1 (B) [170 IAC 6-1-17(B)], the utility may disconnect only as provided in Rule 16.1 (C) [170 IAC 6-1-17(C)].

(D) Time. (1) No utility may disconnect service unless it is done between the hours of 8:00 A.M. and 3:00 P.M., prevailing local time. Disconnections pursuant to Rules 16 (A) and 16 (B) [subsections (A) and (B) of this section] are not subject to this limitation.

(2) A utility may not disconnect service for non-payment on any day on which the utility office is closed to the public, or after twelve noon (12:00 noon) of the day immediately preceding any day on which the utility office is not open to the public.

(E) Notice Required Prior to Involuntary Disconnection. (1) Except as otherwise provided herein, service to any residential customer shall not be disconnected for a violation of any rule or regulation of a utility or for the non-payment of a bill, except after seven (7) days prior written notice to such customer by either:

(a) Mailing the notice to such residential customer at the address shown on the records of the utility; or,

(b) Personal delivery of the notice to the residential customer or a responsible member of his household at the address shown on the records of the utility.

(c) No disconnect notice for non-payment may be rendered prior to the date on which the account becomes delinquent.

(2) The notice must be in language which is clear, concise, and easily understandable to a layman and shall state in separately numbered large typed or printed paragraphs

(a) the date of proposed disconnection;

(b) the specific actual basis and reason for the proposed disconnection;

(c) the telephone number of the utility office at which the customer may call during regular business hours in order to question the proposed disconnection or seek information concerning his rights;

(d) a reference to the pamphlet or the copy of the rules furnished to the customer pursuant to Rule 16.2 [170 IAC 6-1-18] for information as to the customer's rights.

(F) Procedure for Involuntary Disconnection. (1) Immediately preceding the actual disconnection of service, the employee of the utility designated to perform such function shall make a reasonable attempt to identify himself to the customer or any other responsible person then upon the premises and shall announce the purpose of his presence and shall make a record thereof to be maintained for at least thirty (30) days.

(2) The employee shall have in his possession information sufficient to enable him to inform the customer or other responsible person of the reason for disconnection, including the amount of any delinquent bill of the customer, and shall request from the customer any available verification that the outstanding bill has been satisfied or is currently in dispute pursuant to review under Rule 16.1 (B) [170 IAC 6-1-17(B)]. Upon the presentation of such credible evidence, service shall not be disconnected.

(3) The employee shall not be required to accept payment from the customer or other responsible person in order to prevent the service from being disconnected. The utility shall notify its customers pursuant to Rule 16.2 [170 IAC 6-1-18] of its policy with regard to the acceptance or non-acceptance of payment by such employee, and shall uniformly follow such policy without discrimination.

(4) When the employee has disconnected the service, he shall give to a responsible person at the customer's premises, or if no one is at home, shall leave at a conspicuous place on the premises, a notice stating that service has been disconnected and stating the address and telephone number of the utility where the customer may arrange to have service reconnected.

(G) Reconnection. (1) A utility may charge a reasonable reconnection charge, not to exceed the charge approved by the Commission in the utility's filed tariffs. A utility shall inform its customers of such reconnection fee pursuant to Rule 16.2 [170 IAC 6-1-18].

(2) If the utility disconnects service in violation of these rules [170 IAC 6-1], the service shall immediately be restored at no charge to the customer.

(3) The utility must reconnect the service to the customer as soon as reasonably possible but at least within one (1) working day after it is requested to do so; provided however, that the utility shall not be required to reconnect the service until

(a) the conditions, circumstances or practices which caused the disconnection have been corrected;

(b) payment of all delinquent charges owed the utility by the customer and any deposit authorized by these rules [170 IAC 6-1] has been made; and

(c) a responsible person is present in the premises to see that all water outlets are closed to prevent damage from escaping water.

(Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 16; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 687; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1-17 Customer complaints

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2

Sec. 17. Complaints and Review. (A) Complaint Procedure. (1) A customer may complain at any time to a utility about any bill which is not delinquent at that time, security deposit, disconnection notice, or any other matter relating to its service and may request a conference thereon. Such complaints may be made in person, in writing, or by completing a form available from either the Commission or from the utility at its business offices. A complaint shall be considered filed upon receipt by the utility, except mailed complaints shall be considered filed as of the postmark date. In making a complaint and/or request for conference, the customer shall state at a minimum, his name, service address, and the general nature of his complaint.

(2) Upon receiving each such complaint or request for conference, the utility:

(a) shall promptly, thoroughly and completely investigate such complaint, confer with the customer when requested and notify, in writing, the customer of the results of its proposed disposition of the complaint after having made a good faith attempt to resolve the complaint.

(b) Such written notification shall advise the customer that he may, within seven (7) days following the date in which such notification is mailed, request a review of such proposed disposition by the commission.

(B) Review. (1) If the customer is dissatisfied with the utility's proposed disposition of the complaint as provided in 16.1 (A) (2) [subsection (A)(2) of this section], he may request the Commission in writing within seven (7) days following the date on which such notification is mailed, to informally review the disputed issue and the utility's proposed disposition thereof. Such request shall certify that the customer has also sent a copy of his request for review to the utility involved. Upon receiving such request, the Commission shall provide an informal review within twenty-one (21) days. The review shall consist of not less than a prompt and thorough investigation of the dispute and shall result in a written decision to be mailed to the customer and the utility within thirty (30) days after its receipt of the customer's request. Upon request by either party or the Commission, the parties shall be required to meet and confer to the extent and at such place as the Commission may consider to be appropriate.

(2) The records of the Commission relating to such reviews shall be kept in a systematic order.

(C) Continuation of Service Pending Disposition of Complaint. (1) If the customer is receiving service at the time the complaint and/or request for conference provided for in 16.1 (A) (1) [subsection (A)(1) of this section] above is received by the utility, his service shall not be disconnected until ten (10) days have elapsed from the date of mailing of the notification of the utility's proposed disposition of his complaint. Provided, however, that if a review by the Commission of the utility's proposed disposition of the complaint is requested by the customer as provided by 16.1 (B) (1) [subsection (B)(1) of this section] within seven (7) days after the mailing of such proposed disposition of the complaint, the utility shall not disconnect the customer's service until at least three (3) days have elapsed from the date of mailing of the Commission's decision upon and pursuant to such review if the customer who has requested such review has paid and continues to pay all undisputed bills, portions of disputed bills as specified in 16.1 (C) (2) [subsection (C)(2) of this section] below, and pays all future undisputed bills prior to their becoming delinquent.

(2) In those instances when the customer and utility cannot agree as to what portion of a bill is undisputed, it shall be sufficient that the customer pay on the disputed bill an amount equal to his average bill for the twelve (12) months immediately preceding the disputed bill except in those cases where the customer has received fewer than twelve (12) bills, in which event the customer shall pay an amount equal to 1/12 of the estimated annual cost of service to be rendered to the customer.

(D) Record of Complaints. (1) Each utility shall keep a written record of complaints and requests for conferences pursuant to Rule 16.1 [this section]. Such records shall be retained at the office or branch office of the utility or in the respective department office thereof where such complaints were received and/or any conferences were subsequently held. Such written records are to be readily available upon request by the concerned customer, his agent possessing written authorization, or the Commission.

(2) Each utility shall annually submit a report to the Commission which shall state and classify the number of complaints made to the utility pursuant to Rule 16.1 [this section], the general nature of the subject matter thereof, how received (in person, by letter, etc.) and whether a Commission review was conducted thereon.

(Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 16.1; filed Nov 28, 1977, 3:00 pm; Rules and Regs. 1978, p. 691; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1-18 Informational pamphlets; rate schedules; notice of proposed rate change

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2

WATER UTILITIES

Sec. 18. Information Provided by Utilities to Applicants and Customers. (A) All utilities except Class D water utilities must publish and distribute, without request, to all applicants for service and to all current customers, a comprehensive pamphlet which, in clear language, easily understandable to a layman, fully describes the rights and responsibilities of the customers. For Class D utilities it shall be sufficient to distribute a copy of Rules 11 to 16.2 [170 IAC 6-1-11–170 IAC 6-1-18] of these rules to their customers and applicants for service.

(B) A utility shall supply free of charge a copy of the rate schedules applicable to the types of service available to new applicants for and existing customers of residential service, upon request by the applicant or customer.

(C) Each utility, whenever it petitions the Commission for a change in any of its base rate schedules must furnish to each customer within forty-five (45) days of such request and prior to the date of the public hearing a notice which fairly summarizes the nature and extent of the proposed changes. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 16.2; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 692; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-19 Station meters and pressure surveys; records

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33

Sec. 19. Station Meters and Pressure Surveys. (A) Each utility furnishing water service shall install at each supply station such station meters and instruments as may be necessary to obtain a daily and monthly record of the total amounts of water delivered into the mains.

(B) Each utility furnishing water service to more than 750 but less than 1,500 customers shall maintain a graphic recording pressure gauge at its plant, downtown office, or at some central point in the distribution system where continuous records shall be made of the pressure in the mains at that point.

(C) Utilities furnishing water service to 1,500 or more customers shall equip themselves with one or more portable graphic recording pressure gauges, in addition to the foregoing, and shall make records, each covering at least a 24-hour period, of the water pressure at sufficiently frequent intervals and at a sufficient number of points on the system to provide an adequate record of system pressures. The records or charts made by these meters shall be identified, dated and kept on file and available for inspection for a period of three years. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 17; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 693; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-20 Water quality standards

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33

Sec. 20. Quality. (A) Water furnished by any water utility for human consumption or for domestic use shall be of such quality as will have the approval, or comply with the requirements, of the Indiana State Board of Health.

(B) (1) Public water supplies within the distribution pipe systems shall be adequately protected against pollution from back siphonage or cross connections with other systems on customer's property by proper installation of protective devices in accordance with the rules of the Indiana State Board of Health. Such protective devices shall be installed and maintained at the cost and expense of the customer, subject however, to the inspection test and approval of the utility before being placed in service, and at such times thereafter as recommended by the Indiana State Board of Health.

(2) Public water supplies shall also be adequately protected against any unnecessary and avoidable pollution at their own sources, and at all times after being taken therefrom, until delivery to the customer, to conform in all cases to the requirements of the Indiana State Board of Health. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 18; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 693; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-21 Flushing mains; records

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33

Sec. 21. Flushing Mains. (A) Proper provision shall be made for flushing those parts of a distribution system which need flushing in order to eliminate or minimize complaints from customers arising from discoloration or other abnormal conditions of the

water.

(B) Records shall be kept of all flushings of mains, showing date, place and duration, and such records shall be used as a guide in determining the necessary frequency of flushing of the same mains thereafter. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 19; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 693; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-22 Interruptions in service; notice to customers

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-12; IC 8-1-2-113

Sec. 22. Interruptions of Service. Each utility shall keep a record of any interruption of service affecting its entire system or major division thereof, including a statement of the time, duration, extent and cause of the interruption. Whenever the service is intentionally interrupted for any purpose, such interruption shall, except in emergencies, be at a time during regular working hours of the utility which will cause the least inconvenience to customers. Customers who will be affected by such interruption shall, to the extent practical, be notified in advance. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 20; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 693; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-23 Accident reports

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-114

Sec. 23. Accidents. In addition to the reports required by statute, every utility shall give notice to the Commission of each serious accident occurring upon its or its customer's premises when the same is accompanied by flooding with water from the utility's system, and is attended with serious damage to property or human life. Said notice shall be given within 24 hours of the utility's knowledge of such accident. A written report shall also be made if the same is required by the Commission.

Neither said notice nor report shall imply or be considered an admission of any liability or responsibility in connection with the accident. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 21; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 694; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-24 Customer request for modification; liability for costs

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-4; IC 8-1-2-101

Sec. 24. Modification at Customer's Expense. If a customer requests for his convenience or by his actions requires that utility facilities be redesigned, reengineered, relocated, removed, modified, or reinstalled, the utility may require the customer to make payment to it of the full cost of performing such service. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 24; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 694; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-25 Extension of water mains (Repealed)

Sec. 25. (*Repealed by Indiana Utility Regulatory Commission; filed Dec 5, 1990, 3:35 p.m.: 14 IR 566*)

170 IAC 6-1-26 Rate schedules, rules and regulations; filing; public inspection

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-38; IC 8-1-2-39; IC 8-1-2-40

Sec. 26. Filing and Posting of Rate Schedules, Rules and Regulations of the Utility and of the Commission. Copies of all schedules of rates for service, forms of contracts, charges for service connections and extensions, and of all rules and regulations covering the relationship between the customer and the utility shall be filed by each utility in the office of the Commission. Complete schedules, contract forms, rules and regulations, etc., if filed with the Commission, shall also be on file in the local office of the

utility, and shall be open to the inspection of the public. The attention of the public shall be called to these files of schedules, rules and regulations, by placing a suitable placard in that part of the office open to the public. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 26; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 700; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-27 Date of compliance with rules

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-1-3

Sec. 27. Date of Compliance with Rules. All water utilities shall comply with these Rules, Regulations, and Standards of Service [170 IAC 6-1] as soon as practicable and be in full compliance within 180 days after their date of effectiveness. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 27; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 700; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1-28 Saving clause

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-1-3

Sec. 28. Saving Clause. The adoption of these rules [170 IAC 6-1] shall in no way preclude the Commission from altering or amending the same, in whole or in part, or from requiring any additional service, equipment, facility or standards, whether upon complaint or upon its own motion, or upon the application of any utility; and, further, these rules [170 IAC 6-1] shall in no way relieve any utility from any of its duties under the laws of this State. (*Indiana Utility Regulatory Commission; No. 34805: Standards of Service For Water Utilities Rule 28; filed Nov 28, 1977, 3:00 pm: Rules and Regs. 1978, p. 700; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

Rule 1.1. Distribution System Improvement Charges (DSIC)

170 IAC 6-1.1-1 Definitions

Authority: IC 8-1-1-3; IC 8-1-31-17

Affected: IC 8-1-2; IC 8-1.5-3-8

Sec. 1. (a) The definitions in this section apply throughout this rule.

(b) "Commission" means the Indiana utility regulatory commission.

(c) "Distribution system" means:

- (1) distribution mains;
- (2) valves;
- (3) hydrants;
- (4) service lines;
- (5) meters;
- (6) meter installation;
- (7) and other appurtenances;

necessary to transport treated water from the point it exits the treatment facility to the point at which it is delivered to the customer.

(d) "Distribution system improvement charges" or "DSIC" means a distribution system improvement charge approved under IC 8-1-31.

(e) "DSIC costs" means depreciation expenses and the pretax return associated with eligible distribution system improvements.

(f) "DSIC revenues" means utility revenues produced through a DSIC exclusive of revenues from all other rates and charges.

(g) "Eligible distribution system improvements" means new used and useful water utility plant projects that:

- (1) do not increase revenues by connecting the distribution system to new customers;
- (2) are in service; and
- (3) were not included in the utility's rate base in its most recent general rate case.

(h) "Utility" means every public or municipally-owned utility.

- (i) "Public utility" means every:
 - (1) corporation;
 - (2) company;
 - (3) partnership;
 - (4) limited liability company;
 - (5) individual; or
 - (6) association of individuals;

or their lessees, trustees, or receivers appointed by a court, that may own, operate, manage, or control any plant or equipment within the state for the production, delivery, or furnishing of water.

(j) "Municipally-owned utility" includes every utility owned or operated by a municipality.

(k) "Pretax return" means the following:

(1) For investor-owned utilities the revenue necessary to:

(A) produce net operating income equal to the utility's weighted cost of capital multiplied by the original cost of eligible distribution system improvements; and

(B) pay any state and federal income taxes applicable to such income.

(2) "Pretax return" for a municipally-owned utility:

(A) the average annual debt service associated with the distribution system improvement; or

(B) the return on plant under IC 8-1.5-3-8 granted in its most recent rate case computed by multiplying the authorized return times the cost of eligible distribution system improvement.

(Indiana Utility Regulatory Commission; 170 IAC 6-1.1-1; filed Sep 27, 2005, 8:45 a.m.: 29 IR 456)

170 IAC 6-1.1-2 Applicability and scope

Authority: IC 8-1-31-8

Affected: IC 8-1-2; IC 8-1-31

Sec. 2. (a) This rule applies to any utility that may now or hereafter be engaged in providing water service, subject to the jurisdiction of the commission.

(b) This rule shall in no way prohibit the recovery by a utility of costs that meet the statutory criteria of IC 8-1-31 et seq., including costs not otherwise included under Account 331, 333, 334, or 335 of the National Association of Regulatory Utility Commissioners' Uniform System of Accounts for Water Utilities, provided that the costs for which recovery is requested were incurred in a project within the utility's existing distribution system and not in projects that connect to new customers. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.1-2; filed Sep 27, 2005, 8:45 a.m.: 29 IR 457)*

170 IAC 6-1.1-3 Exemption

Authority: IC 8-1-31-8

Affected: IC 8-1-2; IC 8-1-31

Sec. 3. A utility may not file a petition under this rule in the same calendar year in which the utility has filed a request for a general increase in the basic rates and charges of the utility. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.1-3; filed Sep 27, 2005, 8:45 a.m.: 29 IR 457)*

170 IAC 6-1.1-4 Filing

Authority: IC 8-1-31-8

Affected: IC 8-1-2; IC 8-1-31

Sec. 4. (a) The utility shall file with the commission rate schedules establishing a DSIC that will allow the automatic adjustment of the utility's basic rates and charges to provide for recovery of DSIC costs. Any petition filed to initiate a DSIC proceeding, which shall be deemed the utility's case-in-chief, shall include as attachments any:

- (1) schedules;
- (2) forms;
- (3) testimony;

(4) exhibits; or

(5) other required supporting documentation;

as provided in section 5 of this rule.

(b) The utility shall serve the office of the utility consumer counselor a copy of its filing at the time of its filing with the commission. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.1-4; filed Sep 27, 2005, 8:45 a.m.: 29 IR 457*)

170 IAC 6-1.1-5 Required supporting documentation

Authority: IC 8-1-31-8

Affected: IC 8-1-2-49; IC 8-1-31

Sec. 5. (a) The utility shall submit the following supporting documentation for its petition to the commission:

(1) A description of the DSIC project, an explanation of why the project is needed, the benefits resulting to the utility and its customers upon completion of the project, and the age of the plant that was retired.

(2) A statement that the project is in service and was not included in the utility's rate base in its most recent general rate case. Provide the cause number and date of the utility's most recent rate order.

(3) A statement that the project will not result in an increase in revenue resulting from the connection of new customers to the utility's distribution system.

(4) A statement that all necessary local, state, and federal permits, approvals, and authorizations applicable to the DSIC project have been obtained.

(5) A statement regarding whether any affiliate (as defined by IC 8-1-2-49) was directly or indirectly engaged by the utility in connection with the installation of the infrastructure that is the subject of the proposed DSIC and a copy of any such affiliated interest contract.

(6) A statement regarding whether the utility plans to replace other distribution infrastructure in the next five (5) years and a general outline of any such plans.

(7) A new tariff reflecting the requested DSIC in the same format as the existing tariff on file with the commission, with clear denotations on all schedules where the DSIC rate is applicable.

(8) A statement that the utility:

(A) has invoices and other cost support for every item included in the project cost form; and

(B) is prepared to file such invoices if required by the commission or requested by the office of utility consumer counselor.

(9) An affidavit from an officer of the utility attesting to the veracity of the statements and information submitted under this subsection.

(10) When the petition constitutes an application to change an existing DSIC, a statement describing how the utility will satisfy any outstanding reconciliation requirement for its current DSIC.

(11) A statement that the project costs, for which recovery is sought, represent an investment by the utility and not another funding source such as a grant, developer contribution, or transportation department reimbursement.

(12) If the applicant is seeking debt service, a statement including the cause number that the applicant has previously obtained IURC approval to issue the long term debt.

(b) By submitting documentation in compliance with subsection (a), the utility makes a prima facie case for the eligibility of the improvements and the reasonableness of the charges. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.1-5; filed Sep 27, 2005, 8:45 a.m.: 29 IR 457*)

170 IAC 6-1.1-6 Response

Authority: IC 8-1-31-8

Affected: IC 8-1-2; IC 8-1-31

Sec. 6. (a) The office of utility consumer counselor or other intervening party may submit a report to the commission indicating its opposition to or support of each portion of the petition within thirty (30) days after the petition is filed. The filing utility may then file its rebuttal within seven (7) days. The office of utility consumer counselor may examine information of the utility to determine whether:

(1) the system improvements are in accordance with the requirements of section 1(f) of this rule; and

(2) the utility properly calculated the proposed charges.

(b) For purposes of discovery, the period for responses shall be four (4) business days instead of ten (10) days. The remaining provisions of 170 IAC 1-1.1-16 shall apply. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.1-6; filed Sep 27, 2005, 8:45 a.m.: 29 IR 458*)

170 IAC 6-1.1-7 Hearing and order

Authority: IC 8-1-31-9

Affected: IC 8-1-2; IC 8-1-31

Sec. 7. (a) Except as provided in subsection (b) or for good cause shown, the commission shall hold the hearing and issue its order not later than sixty (60) days after the petition is filed.

(b) If, subsequent to the filing of its petition, the utility files additional testimony or exhibits, other than rebuttal, to supplement its case-in-chief, or for good cause shown, the commission may reset the sixty (60) day hearing deadline established in subsection (a) of this section. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.1-7; filed Sep 27, 2005, 8:45 a.m.: 29 IR 458*)

170 IAC 6-1.1-8 Reconciliation procedure

Authority: IC 8-1-31-9

Affected: IC 8-1-2; IC 8-1-31

Sec. 8. (a) Any utility authorized to implement a DSIC shall file with the commission, no later than thirty (30) days after the expiration of each twelve (12) month period in which the DSIC rate was in effect, a report that reconciles the difference between the DSIC revenues and the DSIC costs. The utility shall serve a copy of the report simultaneously on the office of the utility consumer counselor. Within fifteen (15) days of service, the office of the utility consumer counselor shall submit its comments to the commission and serve a copy on the utility. Upon review of the utility's report and the office of utility consumer counselor's comments, the commission may, at its discretion, convene a hearing after notice to adjust the DSIC to reconcile over recovery or under recovery of the underlying DSIC costs.

(b) In the event the utility is later authorized to change its DSIC, then the annual reconciliation shall be twelve (12) months following the authorization of the change in the DSIC, with the first reconciliation also covering the period between the last reconciliation of the previously approved DSIC and authorization to change the DSIC (the "interim period"). Reconciliation for the interim period shall use the DSIC revenues and DSIC costs associated with the DSIC in effect at the time. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.1-8; filed Sep 27, 2005, 8:45 a.m.: 29 IR 458*)

Rule 1.5. Extension of Water Mains

170 IAC 6-1.5-1 "Applicant" defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12

Affected: IC 8-1-12

Sec. 1. As used in this rule, "applicant" means a person requesting the main extension in order to receive water utility service from the utility. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-1; filed Dec 5, 1990, 3:35 p.m.: 14 IR 559; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-2 "Commission" defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12

Affected: IC 8-1-12

Sec. 2. As used in this rule, "commission" refers to the Indiana utility regulatory commission. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-2; filed Dec 5, 1990, 3:35 p.m.: 14 IR 559; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-3 “Completion date of the main extension” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 3. As used in this rule, “completion date of the main extension” means the date the utility declares the main extension to be in service and releases it for taps. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-3; filed Dec 5, 1990, 3:35 p.m.: 14 IR 559; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-4 “Cost of connecting” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 4. As used in this rule, “cost of connecting” means the average of the utility's costs for the same size service connection incurred during the preceding calendar year including, if provided by the utility, the service pipe, service stop, meter and meter vault, tap, and installation thereof or portions thereof; however, the cost of connecting shall not be applicable under this rule for those portions of such cost recovered from an applicant by a utility in the form of a tap or similar charge. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-4; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-5 “Cost of the main extension” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 5. As used in this rule, “cost of the main extension” means the cost of installing the main as determined in sections 31 through 32 of this rule. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-5; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-6 “Customer” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 6. As used in this rule, “customer” means a person being supplied with water utility service. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-6; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-7 “Deposit” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 7. As used in this rule, “deposit” means the amount required to be deposited by or on behalf of each applicant or prospective customer for a main extension prior to the utility commencing construction of the main extension. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-7; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-8 “Estimated annual revenue” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 8. As used in this rule, “estimated annual revenue” for an applicant connecting to the main means the utility's average annual revenue per applicant from comparable customers in the calendar year preceding such connection, adjusted to reflect any changes in the applicable rates and charges of the utility for such service. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-8; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-9 “Frontage” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 9. As used in this rule, “frontage” means the footage, ten (10) feet minimum length, of a lot or tract (but not an easement) boundary that is parallel to or curvilinear to, and immediately adjacent to a main extension in a public thoroughfare or easement. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-9; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-10 “Immediate revenue allowance” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 10. As used in this rule, “immediate revenue allowance” means the amount of three (3) times the estimated annual revenue less the cost of connecting for an applicant. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-10; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-11 “Lot” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 11. As used in this rule, “lot” means a parcel of land as platted or, if the area to be served is not platted, the equivalent of a parcel of land as determined in accordance with section 30 of this rule. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-11; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-12 “Main” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 12. As used in this rule, “main” means a pipe owned by the utility which delivers water to fire hydrants and service pipes. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-12; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-13 “Main extension” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 13. As used in this rule, “main extension” means the mains, hydrants, and appurtenances installed by the utility to provide the water utility service requested by or on behalf of the applicant or prospective customer, but does not include the service pipes. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-13; filed Dec 5, 1990, 3:35 p.m.: 14 IR 560; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-14 “Original depositor” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 14. As used in this rule, “original depositor” means an applicant who enters into a main extension agreement and makes a deposit with the utility. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-14; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-15 “Person” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 15. As used in this rule, “person” means an individual, firm, corporation, governmental agency, or other entity. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-15; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-16 “Prospective customer” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 16. As used in this rule, “prospective customer” means a person who is not an original depositor, but whose lot or frontage directly abuts the main extension between its original beginning and its original end point. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-16; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-17 “Public thoroughfare” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 17. As used in this rule, “public thoroughfare” means a road, street, or way which has been dedicated for use by the public and accepted by the appropriate governmental authority. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-17; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-18 “Refund” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 18. As used in this rule, “refund” means the subsequent connector's fees, subsequent connector's revenue allowances, and revenue allowances from depositor-authorized connections of lots included in the original depositor's main extension agreement that must be paid by the utility to the original depositor for ten (10) years after the completion date of the main extension. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-18; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-19 “Revenue allowance from depositor-authorized connection” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 19. As used in this rule, “revenue allowance from depositor-authorized connection” means the amount of three (3) times the estimated annual revenue less the cost of connecting that the utility may refund to original depositor for connections for lots or unplatted areas owned, controlled, or designated by the original depositor and does not include an immediate revenue allowance. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-19; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-20 “Service pipe” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 20. As used in this rule, “service pipe” means a supply line leading directly into the premises supplied or to be supplied from the main adjacent to such premises. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-20; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-21 “Service stop” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 21. As used in this rule, “service stop” means a valve inserted in the service pipe between the main and the meter for the purpose of turning water on and off. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-21; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-22 “Subsequent connector” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 22. As used in this rule, “subsequent connector” means a person who was not an original depositor but subsequently applies for water service and who connects to the main within ten (10) years after the completion date of the main extension. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-22; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-23 “Subsequent connector's fee” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 23. As used in this rule, “subsequent connector's fee” means the cash fee equal to the cost per lot of the main extension determined in accordance with sections 30 through 32 of this rule, multiplied by the number of lots for which service is requested. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-23; filed Dec 5, 1990, 3:35 p.m.: 14 IR 561; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-24 “Subsequent connector's revenue allowance” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 24. As used in this rule, “subsequent connector's revenue allowance” means three (3) times the estimated annual revenue for the subsequent connector less the cost of connecting. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-24; filed Dec 5, 1990, 3:35 p.m.: 14 IR 562; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-25 “Tap” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 25. As used in this rule, “tap” means a fitting owned by the utility and inserted by it into a main to which a service pipe is attached. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-25; filed Dec 5, 1990, 3:35 p.m.: 14 IR 562; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-26 “Total required deposit” defined

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 26. As used in this rule, “total required deposit” means the amount by which the cost of the main extension exceeds the immediate revenue allowance for the original depositor. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-26; filed Dec 5, 1990, 3:35 p.m.: 14 IR 562; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-27 Free extension

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 27. A utility, upon written request for service by an applicant, shall extend a main and connect the applicant free of charge to provide the service requested if:

- (1) the cost of the main extension does not exceed the immediate revenue allowance for the applicant; and
- (2) the applicant agrees to take service within nine (9) months following the completion date of the main extension.

(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-27; filed Dec 5, 1990, 3:35 p.m.: 14 IR 562; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1.5-28 Main extension; exception to commission approval

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 28. If the cost of the main extension is greater than the free extension cost provided in section 27 of this rule, that extension shall be made, upon receipt by the utility of a signed agreement and a deposit from the applicant, without specific approval of the agreement by the commission. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-28; filed Dec 5, 1990, 3:35 p.m.: 14 IR 562; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

170 IAC 6-1.5-29 Main extension route

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 29. (a) The utility shall use good engineering and water utility practices in determining the route for all main extensions.

(b) The utility shall determine the total length of the extension from its existing main to serve the extension to the end of the lot or frontage of the most remote applicant to be served.

(c) However, if the end lot or frontage is a corner lot or frontage abutting an intersecting street in which an existing main is located, the end of the new extension must connect with the existing main located in that intersecting street.

(d) If the end lot or frontage is a corner lot or frontage abutting an intersecting street in which no main is located, the end of the new extension may not extend beyond the intersecting street corner of that lot.

(e) If the street in which the main is to be laid dead ends in a cul-de-sac or appears to be permanently dead ended against a railroad, creek, river, or other major physical or natural barrier, the end point of the main extension, if serving the most remote lot or frontage, shall be the point of the most remote service pipe connection, which connection point shall be at least ten (10) feet beyond the lot line. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-29; filed Dec 5, 1990, 3:35 p.m.: 14 IR 562; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

170 IAC 6-1.5-30 Number of lots served by main extension

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 30. A determination shall be made of the number of lots to be served by the main extension. The determination may include only lots which directly abut the main extension between its original beginning and its original end point. If any part of the main extension is located within an area platted or to be platted, the number of lots shown within the plat to be served shall be included in the determination. If any part of the main extension is located in an unplatted area, the number of lots to be included shall be determined by dividing the total frontage of the main extension within the unplatted area on either or both sides of the public thoroughfare or easement in which the main is located by one hundred (100) feet and rounded to the nearest whole number of lots, provided either or both sides are available for future development and not restricted against usage because of limited access or other reasons. The determination of the number of lots for a particular extension may include a combination of platted and unplatted lots as defined in this section. Any further main extension subsequently connected to the original main extension shall, for all purposes under this rule, constitute a separate main extension. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-30; filed Dec 5, 1990,*

3:35 p.m.: 14 IR 562; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1.5-31 Main extension cost

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12

Affected: IC 8-1-12

Sec. 31. (a) The cost of the main extension may, as determined by the utility, be either:

- (1) the computed cost based on the average costs for similar main extensions experienced by the utility during its preceding fiscal year, plus or minus any amount necessary to adjust for known cost increases or decreases;
- (2) the estimated cost of the extension; or
- (3) the actual cost of a developer-installed extension.

(b) In the absence of representative cost data for the previous year for any size or type of main or for any special construction, or for any other facility involved in a main extension, the cost shall be the utility's best estimate of the cost of the main, special construction, or related facilities based upon current available information.

(c) If the cost of the main extension is computed or estimated under subsection (a)(1) or (a)(2), it shall be based on an eight (8) inch main unless the utility determines that a larger or smaller main is reasonably necessary to serve the applicant, including fire protection service, in which event the cost, computed or estimated, shall be based on the size of main determined reasonably necessary.

(d) If the utility's future extension plans require a larger main than is reasonably necessary to serve the applicants and prospective customers, the difference in the cost for the larger main size and increased material and installation cost, if any, shall be borne by the utility.

(e) The computed or estimated cost may be adjusted to the actual cost by the utility, in which event the actual cost as finally determined shall constitute the cost of the main extension. If the main extension agreement provides for the adjustment of the computed or estimated cost of the main extension to the actual cost, the adjustment shall be made upon completion of the main extension. If the actual cost of the extension is less than the computed or estimated cost, the utility shall refund the difference to the original depositor as soon as the actual cost has been determined. If the actual cost of the extension exceeds the computed or estimated cost, then the utility shall bill the original depositor for, and that depositor shall pay, the difference between the computed or estimated cost and the actual cost.

(f) If the utility determines that a main larger than eight (8) inches is reasonably necessary to serve the domestic and fire protection requirements of the applicant, and those requirements are significantly in excess of the requirements of the other applicants or the prospective customers along the intervening route of the main, the cost of the main extension or deposit for other applicants or subsequent connector's fee for the prospective customers shall be based on the smaller size main that the utility has determined is adequate to meet the requirements of the other applicants or the prospective customers along the intervening route. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-31; filed Dec 5, 1990, 3:35 p.m.: 14 IR 563; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-32 Cost per lot

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12

Affected: IC 8-1-12

Sec. 32. The cost per lot shall be determined by:

- (1) the total number of lots to be served by the main extension divided into the cost of the main extension; or
- (2) the cost of the main extension shall be divided proportionately on the basis of respective lot frontage for all lots to be served by the main extension.

(*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-32; filed Dec 5, 1990, 3:35 p.m.: 14 IR 563; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-33 Cost options

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12

Affected: IC 8-1-12

Sec. 33. (a) The utility shall file with the commission, for approval, its choice of the following options with appropriately revised rules:

(1) For the main extension, the applicant shall be required to pay the cost of the main extension, and the full gross-up state and federal taxes associated with the cost of the extension and the applicant shall receive refunds as provided in sections 36 through 37 of this rule.

(2) For the main extension, the applicant shall be required to pay the cost of the main extension exclusive of the tax associated with the main extension, and the applicant shall receive refunds as provided in sections 36 through 37 of this rule.

(3) For the main extension, the applicant shall be allowed the option of paying the cost of the main extension and full gross-up state and federal taxes associated with the cost of the main extension, and the applicant shall receive refunds as provided in sections 36 through 37 of this rule, or shall pay the cost of the main extension exclusive of the tax associated with the main extension and the applicant shall forfeit all rights to immediate revenue allowances and to refunds, except for subsequent connector's fees.

(b) If the utility desires to change its option after initial filing, the utility shall submit its requested revisions to the commission for approval. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-33; filed Dec 5, 1990, 3:35 p.m.: 14 IR 563; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-34 Total required deposit

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12

Affected: IC 8-1-12

Sec. 34. (a) In the case of a residential real estate development, immediate revenue allowance may not be deducted from the cost of the main extension in determining the amount of the total required deposit, except for those residential dwelling units, if any, where construction has commenced above the first floor level.

(b) In the case of a commercial or industrial real estate development, immediate revenue allowance may not be deducted from the cost of the main extension in determining the amount of the total required deposit, except where building construction has commenced and pertinent data, such as customer types, service pipe, metering arrangements, and water demands, have been furnished to the utility, to allow the utility to determine the estimated annual revenue from that development.

(c) The total required deposit for a main extension may either be made in a cash payment, or it may be secured by an irrevocable letter of credit acceptable to the utility and issued by a national banking association or a bank chartered under the laws of the state. The deposit may also be secured in any other manner which is mutually acceptable to the parties and which guarantees payment of the deposit immediately upon completion of the main extension.

(d) If permitted by the utility, the main extension may be installed by the developer or the developer's contractor according to the extension and installation policies of the utility, and the actual cost of the developer-installed extension shall be considered the total required deposit.

(e) A utility may allocate, or permit original depositors to allocate, the total required deposit on the basis of the number of lots, the respective lot frontage, or any other basis mutually acceptable to the original depositors. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-34; filed Dec 5, 1990, 3:35 p.m.: 14 IR 564; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-35 Subsequent connector fee

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12

Affected: IC 8-1-12

Sec. 35. (a) Within ten (10) years after the completion date of the main extension, a utility shall not permit a subsequent connector to connect to a main extension until after the subsequent connector has paid the required subsequent connector's fee to the utility.

(b) Applicants for service connections for lots in subdivision and tract developments which are included in the original depositor's main extension agreement, are not required to pay a subsequent connector's fee, unless otherwise specifically provided for in the main extension agreement.

(c) If a prospective customer with frontage land that was unplatted on one (1) or both sides of the street at the time the main extension was installed later subdivides this frontage prior to the expiration of the ten (10) years after the completion date of the main extension in such a manner that some or all lots will not require service directly from that main extension, the customer is considered

to have requested a lateral extension from that main extension to serve the customer's land. The utility, in that case, shall collect from the prospective customer prior to installing the requested lateral main extension, a subsequent connector's fee for each equivalent lot of the frontage land used in determining the main extension cost per lot and which will not be served directly by the original main extension. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-35; filed Dec 5, 1990, 3:35 p.m.: 14 IR 564; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-36 Refunds

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 36. (a) Refunds shall be paid for a period of ten (10) years after the completion date of the main extension to the original depositor in proportion to the respective deposits, unless the original depositor for the main extension forfeited all rights to refunds, except subsequent connector's fees, as provided in section 33(a)(3) of this rule.

(b) However, no refunds shall be required to be made by the utility until the number of customers actually connected to the main extension equals the number of applicants for which an immediate revenue allowance was included in computing the total required deposit for the main extension. The refunds shall be paid annually or more frequently at regular intervals at the discretion of the utility.

(c) Total refunds to any original depositor shall not exceed the amount of the original deposit except in the case of a phased residential real estate development. In this situation the preliminary plat must be submitted to the utility at the time of the first request for a main extension. During the ten (10) year period beginning with the completion date of the first main extension, the amount of any refunds generated in excess of the deposit made on any phase of the development must be applied against the deposit made for any other phase of the development, so long as the total amount of refunds to the original depositor shall not at any time exceed the total amount of his deposits during the period. The utility shall not require any subsequent connector's fee which is in excess of the unrefunded balance of the aggregate of deposits received from all original depositors.

(d) The refund shall be made by mailing the payment to the original depositor's last known address as shown on the books and records of the utility. Any refund distribution which cannot be returned to an original depositor after the refund becomes due and payable must be reported as required by IC 32-9-1-42 [*Repealed by P.L.31-1995, SECTION 9, effective July 1, 1996.*]. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-36; filed Dec 5, 1990, 3:35 p.m.: 14 IR 564; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-37 Deposit

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 37. A deposit shall be held by the utility as a customer's advance for construction. Any deposit which is not subject to refund because of the running of the ten (10) year period as provided in section 36 of this rule, shall be transferred by the utility to contributions in aid of construction. If the original depositor for a main extension forfeits all rights to a refund, except for subsequent connector's fees as provided in section 33(a)(3) of this rule, the payment must be included in contributions in aid of construction, and the associated taxes shall be deducted from contributions in aid of construction. All other deposits must be held as customers' advances for construction until returned to the original depositor or be reported as required by IC 32-9-1-36 [*Repealed by P.L.31-1995, SECTION 9, effective July 1, 1996.*]. (*Indiana Utility Regulatory Commission; 170 IAC 6-1.5-37; filed Dec 5, 1990, 3:35 p.m.: 14 IR 565; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-1.5-38 Basis for costs

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 38. (a) Each utility shall, no later than the first quarter of each year, submit to the commission information used to establish the basis for computed costs for typical main extensions.

(b) If the applicant is required to make any payment, the utility shall, upon request, make the following available to the applicant:

- (1) The information used to establish the basis for the applicable amount as submitted to the commission in compliance with this rule.
- (2) The information used to establish the basis for the estimated annual revenue for a period of three (3) years to be realized by the utility from permanent and continuing customers on main extensions as required by this rule.
- (3) The cost of connecting for the sizes of service connections.

(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-38; filed Dec 5, 1990, 3:35 p.m.: 14 IR 565; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-1.5-39 Extension exception

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 39. A utility shall not be required to make extensions as described in this rule unless the applicants to be initially served by those extensions contract to use the service for a period of three (3) years. A bond may be required of the applicant in this situation. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-39; filed Dec 5, 1990, 3:35 p.m.: 14 IR 565; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

170 IAC 6-1.5-40 Special contract

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 40. (a) A utility may require a special contract when:

- (1) the requested main extension is of such length and the prospective business to be developed by it is so meager as to make it doubtful whether the business from the extension would ever pay a fair return on the utility investment involved in such extension;
- (2) the prospects are that the patronage and demand will not be of such permanency as to warrant the capital expenditure involved;
- (3) there are industrial installations requiring extensive water utility investment and where the demand for water service is expected to be slight, irregular, or of unknown quantity; or
- (4) there are other abnormal or extraordinary circumstances.

(b) The utility and the applicant requesting the extension may enter into a special contract establishing the terms and conditions on which the extension will be made. In the event they are unable to agree on the terms and conditions, the matter, including the contract embodying the terms and conditions, shall be submitted to the commission for determination. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-40; filed Dec 5, 1990, 3:35 p.m.: 14 IR 565; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

170 IAC 6-1.5-41 Prohibition exception

Authority: IC 8-1-1-3; IC 8-1-2-4; IC 8-1-12
Affected: IC 8-1-12

Sec. 41. This rule does not prohibit a utility from making free extensions of lengths greater than specified in this rule or from providing a method of return of deposits for extensions more favorable to original depositors, so long as discrimination is not practiced among applicants or original depositors whose service requirements are similar. *(Indiana Utility Regulatory Commission; 170 IAC 6-1.5-41; filed Dec 5, 1990, 3:35 p.m.: 14 IR 566; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

Rule 2. Classification of Accounts for Class A, B, and C Water Utilities

170 IAC 6-2-1 Classification of accounts; adoption of rules (Repealed)

Sec. 1. *(Repealed by Indiana Utility Regulatory Commission; filed Feb 15, 1990, 4:30 p.m.: 13 IR 1136)*

170 IAC 6-2-2 Classification of accounts for Class A, B, and C water utilities; adoption by reference

Authority: IC 8-1-1-3; IC 8-1-2-10
Affected: IC 8-1-2-10; IC 8-1-2-46

Sec. 2. (a) The rules governing the classification of accounts for Class A, B, and C water utilities operating within the state of Indiana as approved, prescribed, and promulgated by the National Association of Regulatory Utility Commissioners at the 96th Annual Convention on November 26-29, 1984, are adopted by reference.

(b) Copies of the Uniform System of Accounts prescribed for Class A, B, and C water utilities, as approved, prescribed, and promulgated by the National Association of Regulatory Utility Commissioners, as set out at the 96th Annual Convention on November 26-29, 1984, are available for purchase from the National Association of Regulatory Commissioners, Post Office Box 684, Room 1102, Interstate Commerce Commission Building, Washington, D.C. 20044. (*Indiana Utility Regulatory Commission; 170 IAC 6-2-2; filed Feb 15, 1990, 4:30 p.m.: 13 IR 1136; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

Rule 3. Central Station Hot Water Heating Utilities

170 IAC 6-3-1 Statutory provisions and definitions

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-33; IC 8-1-2-34

Sec. 1. Statutory Provisions and Definitions. In accordance with statutory provisions in Sections 36 and 37 [*IC 8-1-2-33, IC 8-1-2-34*], Acts of 1913, the attached code of standards [*170 IAC 6-3*] for central station hot water heating service has been prepared. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 1; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1653; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-2 Definitions; effect of rule; customer compliance with regulations

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-33; IC 8-1-2-34

Sec. 2. Definitions and General Provisions. (a) The word "Utility," used herein, shall be construed to mean public utility; the word "Commission" shall be construed to mean the Public Service Commission of Indiana; the word "Consumer" shall be taken to mean any person, firm, corporation, municipality or other political subdivision of the state supplied by any such utility.

(b) The adoption of these rules and regulations [*170 IAC 6-3*] shall in no way preclude the commission from altering or amending the same in whole or in part, after due notice and public hearing, or from allowing other or requiring additional service, equipment, facility, or standards, either upon complaint or upon its own motion, or upon the application of any utility. These rules [*170 IAC 6-3*] shall not in any way relieve any utility from any of its duties under the laws of this State.

(c) Any utility may decline to serve a consumer or prospective consumer until he has complied with the State and municipal regulations on central station hot water heating service and the reasonable rules and regulations of the utility furnishing the service. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 2; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1653; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-3 Retention of records

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-12

Sec. 3. Records to be Kept in the State. All records required under these standards [*170 IAC 6-3*] shall be preserved for at least three years after they are made. Such records shall be kept within the State, at an office, or offices, of the utility located in the territory served by it, unless otherwise ordered, and shall be open for examination by the commission or its representatives. Each utility shall notify the commission of the office or offices at which the various classes of records are kept. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 3; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1654; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-4 Complaint records

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-12; IC 8-1-2-54

Sec. 4. Complaints, Records of. (a) Each utility shall keep a record of all written complaints received at its office in regard to service which record shall include the name and address of the consumer, the date, nature of complaint, and the remedy. The record shall be available for inspection by duly accredited representatives of the commission.

(b) The commission may require any utility to file with the commission a copy of such record covering any stated interval of time. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 4; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1654; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-5 Station instruments and gauges

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-33; IC 8-1-2-34

Sec. 5. Station Instruments and Gauges. (a) Each utility shall install both indicating and recording thermometers for obtaining the temperature of the water in flow and return mains and also for obtaining the outside temperature.

The thermometers for obtaining the temperature of flow and return water shall be installed so as not to be affected by any local temperature changes other than that of the flow and return water.

The thermometer for obtaining the outside temperature of the atmosphere shall be placed at least one foot from the building in a standard approved case and protected from local conditions tending to give an incorrect indication of the temperature.

(b) Each utility shall install such indicating and recording pressure gauges as may be necessary to obtain the pressure of flow and return water in the mains.

(c) Each utility should install a suitable standard meter in the flow water main which will both indicate and record the amount of water being supplied to the system.

(d) Each utility should install a suitable wind velocity indicator or anemometer. It shall be so located as to indicate the wind velocity in the district served by the utility. Anemometers not of the recording type shall have a record taken of their indications at intervals of one hour. The average velocity of the wind during a period of one minute shall be the velocity recorded. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 5; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1654; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-6 Instrument approval and testing; allowable errors

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-34; IC 8-1-2-35

Sec. 6. Approval and Tests of Instruments and Allowable Errors. (a) All recording and indicating thermometers, gauges, or other instruments used by the utility in connection with its central station heating service shall be of a suitable make and type satisfactory to the commission and shall be subject to the following tests:

(b) Recording thermometers, shall be compared at least once per month and indicating thermometers and gauges shall be compared at least twice during the heating season with standard calibrated indicating instruments. The range of the check observations shall extend, so far as practicable, over approximately two-thirds of the working scale.

(c) A record shall be kept of all tests, which record shall contain all the information necessary to identify the instrument, the date of the test, the results of the test and all readings taken.

(d) The error of the indicating thermometers used to indicate the temperature of the water in the station flow and return mains shall not exceed plus or minus 1 degree between 70° F. and 240° F.

(e) The error of the recording thermometers used to record the temperatures of the water in the station flow and return mains shall not exceed plus or minus 3 degrees between 70° F. and 240° F.

(f) The error of the indicating thermometer used to indicate the temperature of the outside air shall not exceed plus or minus 1 degree between -20° F. and 70° F.

(g) The error of the recording thermometer used to record the temperature of the outside air shall not exceed plus or minus two degrees between -20° F. and 70° F.

(h) A record of the indication, at intervals of one hour, of all indicating thermometers required under this section shall be kept by the utility.

(i) Where recording thermometers are used the utility will not be required to keep a record of the readings of the corresponding indicating thermometers. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 6; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1655; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-7 Map of distribution system; reports

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-12

Sec. 7. Reports to the Commission. Each utility shall file with the commission a map of its distribution system and such reports as the commission may from time to time require. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 7; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1656; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-8 Boiler horsepower

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33

Sec. 8. Boiler Horsepower. There shall be available for use at times of zero weather at least six boiler horsepower capacity for each 1,000 square feet of radiation connected to the utility's mains.

Note.—A boiler horsepower is equivalent to the evaporation of 34.5 pounds of water per hour from feed water of 212° F. to saturated steam at the same temperature. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 8; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1656; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-9 Water flow in mains; pressure variations and surveys

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33; IC 8-1-2-34

Sec. 9. Pressure and Flow of Water in Mains. (a) Pressure Variation. The pressure of the water supplied by any utility as measured at the consumer's service where it enters the building shall not indicate a differential pressure of less than one-half pound per square inch working pressure between flow and return pipes and the average pressure in flow and return service pipes shall be sufficient at all times completely to fill all radiators in the consumer's installation.

(b) Pressure Surveys. Each hot water heating utility shall provide itself with the proper gauges and instruments and shall take and record on order of the commission measurements of the water pressures and variations in pressure throughout the system at points indicated on a map of the distribution system on file with the commission.

(c) Flow. The utility shall be equipped and prepared to furnish at least six pounds of water at the consumer's premises per square foot of radiation per hour. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 9; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1656; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-10 Temperature, pressure and water flow instruments; records

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33; IC 8-1-2-34

Sec. 10. Temperature Pressure and Flow of Water in Mains and Services. (a) Each utility shall provide itself with the proper thermometers and other instruments and shall take and record on order of the commission, the temperature of the water throughout the system at points indicated on a map of the distribution system on file with the commission.

(b) In new installations there shall be provided at the consumer's expense the necessary connections in the consumer's

WATER UTILITIES

installation for taking the temperature and pressure of the flow and return water in the consumer's installation also the necessary connections for the attachment of a portable venturi device for measuring the quantity of water flowing through the installation.

(c) In old installations when there is complaint of inadequacy of service there shall be provided at the consumer's expense the necessary connections in the consumer's installation for taking the temperature, pressure and flow of water as is required in new installations.

(d) The utility shall provide itself with suitable indicating and recording portable instruments to be connected to the consumer's installation for the purpose of determining the quality of service and the quantity of heat being delivered to the consumer during a given period of time. The instruments will consist of thermometers, pressure gauges and a set of venturi tubes. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 10; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1657; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-11 Temperature standards

Authority: IC 8-1-1-3; IC 8-1-2-4
 Affected: IC 8-1-2-33; IC 8-1-2-34

Sec. 11. Station Operating Schedule of Temperatures. (a) The standard for heating service shall be determined by the average temperature of the flow and return water in the mains at the heating plant of the utility and shall not be less than that indicated in the following table showing the average temperatures of flow and return.

(b) The average temperature of station flow and return water shall be determined by dividing by two the sum of the temperature of the water in the flow main and the temperature of the water in the return main.

TABLE I

Table Showing Average Temperatures of Flow and Return Water

Outside Temperature Degrees Fahrenheit	Day Schedule	Permissible Night Schedules	
	6:00 a.m. to 6:00 p.m.	6:00 p.m. to 9:30 p.m. 3:30 a.m. to 6:00 a.m.	9:30 pm. to 3:30 a.m.
70	80	85	70
65	92	98	82
60	102	107	92
55	111	116	101
50	121	126	111
45	129	134	119
40	137	142	128
35	144	148	136
30	151	154	145
25	158	160	154
20	164	165	162
15	170	170	170
10	175	175	175
5	180	180	180
zero	184	184	184
-5	187	187	187
-10	190	190	190
-15	191	191	191
-20	192	192	192

NOTE.—See appendix [170 IAC 6-3-27] for schedule of station flow temperature.

TABLE II

Table Showing Temperature-Lowering Coefficients of Wind Movements

Outside Temperature	Temperature-Lowering Effect per Mile per Hour
50° to 40°	.75 degrees
40 to 30	1.00 degrees
30 to 20	1.10 degrees

WATER UTILITIES

20 to 10	1.20 degrees
10 to 0	1.30 degrees
0 to -10	1.40 degrees
-10 to -20	1.50 degrees

TABLE III
Table Showing Temperature-Lowering Effect of Wind

Outside Temperature	Wind		
	Light 5 to 10 m.p.h.	Medium 10 to 15 m.p.h.	Strong 15 to 20 m.p.h.
50° to 40°	6°	9°	13°
40 to 30	8	13	17
30 to 20	8	14	19
20 to 10	9	15	21
10 to 0	10	16	23
0 to -10	10	17	25
-10 to -20	11	19	26

NOTE.—The plant operator will vary these wind coefficients to suit local conditions.

(Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 11; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1657; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-3-12 Interruption of service; notice to consumer

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-33

Sec. 12. Interruptions of Service. Each utility shall make all reasonable efforts to eliminate interruptions of service, and when such interruptions occur shall endeavor to re-establish service with the shortest possible delay. Whenever the service is to be interrupted for any length of time the consumer shall be notified, if possible, in advance. *(Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 12; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1659; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

170 IAC 6-3-13 Hourly station readings; records

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-12

Sec. 13. Station Records. Each utility shall keep a station record, which record shall show at least the hourly readings of:

- The temperature of the water in the flow main
- The temperature of the water in the return main
- The temperature of the outside atmosphere
- The pressure of the water in the flow main
- The pressure of the water in the return main
- The wind velocity where there is installed a suitable wind gauge.
- Also, the pounds of coal burned per month where it is not practicable to get daily reports.
- The time of starting and shutting down boilers, heating equipment and pumps.
- And such other data as is required to determine the characteristics of the load.

(Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 13; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1660; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-3-14 Sediment in mains; blowout pipes

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-101

WATER UTILITIES

Sec. 14. Sediment in Mains. Each utility shall provide blow-out pipes, on all lateral extensions of mains and at other necessary places in the distribution system for the removal of sediment in the mains. The mains shall be maintained free of sediment. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 14; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1660; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-15 Bills

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-4; IC 8-1-2-33

Sec. 15. Billing of Consumer for Service. (a) Bills rendered periodically to consumers for hot water heating service shall show the number of square feet of radiation set, all flat rate charges, and the price per unit of service. On all bills which are computed on any other basis than a definite charge per unit of service, the other factors used in computing the bills shall be clearly stated so that the amount may be readily computed from the information appearing on the bill.

(b) The billing for all consumers having new heating installation or altered heating installation, shall be based upon the radiation set in the consumer's premises.

(c) Bills rendered to old consumers or to consumers whose radiation has not been altered shall be based upon the radiation set when the amount of radiation set is the correct amount as determined by inspection or test made by the utility subject to the approval of the commission.

(d) The total square feet of radiation set in any consumer's installation shall include in addition to the cast iron radiators, all exposed piping, indirect radiation and such other radiating surfaces which are not covered by suitable pipe covering.

(e) The consumer shall install storm sash strips or other equally effective protections to the doors and windows and keep them securely fastened in place and maintained so during the heating season so as to reduce the amount of radiation required and to conserve the heat.

(f) The company shall at all times exercise reasonable diligence in supplying water in sufficient amount and of such a temperature, as will reasonably heat the premises of the consumer, with all windows and other openings properly closed and maintained.

(g) The company shall furnish hot water in a sufficient quantity to heat the building to a temperature of not less than 70 degrees Fahr., when the outside temperature is zero degrees Fahr., and above provided that sufficient radiation be installed by the consumer to maintain the desired temperature.

(h) The consumer shall not in any manner change, divert or use the water circulating through said interior system and through said connections or permit the same to be so changed, diverted or used, and shall exercise at all times reasonable care for the protection of the utility's property on the premises and shall not install any additional radiation in said premises without the written consent of the utility, and properly identified authorized agents and employees of the utility shall have the right to enter at all reasonable hours upon the premises for the purpose of inspecting the interior system and connections; the consumer shall at all times keep the interior system and the building in good repair and condition at his own expense, and the outside openings properly closed so as to exclude the outside air in cold weather during the heating season; and the utility shall not be liable for any failure of circulation in the interior system nor for damage to person or property arising directly or indirectly from the furnishing of the heat on the premises or for defects in the interior system. However, controlling devices and shut-off valves located on the consumer's premises shall be installed at the expense of the consumer and maintained at the expense of the utility.

(i) The consumer shall prevent all persons other than the duly authorized representatives of the utility from making use of the shut-off cocks of the heating connections outside of the building; when the circulation is once established and the water turned on, such service shall not be discontinued except by an authorized representative of the utility; the utility may seal all drain valves between the heating system and the sewer.

(j) The utility is advised, in so far as it is possible to contract for service with no other party than the owner of the building to be heated. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 15; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1660; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-16 Indirect radiation; rate

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-32; IC 8-1-2-33; IC 8-1-2-39

Sec. 16. Indirect Radiation. Indirect radiation is not recommended but when installed shall be charged for at a rate, 100% in excess of the rate for direct radiation. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 16; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1662; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-17 Underset radiation; rate increase

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-32; IC 8-1-2-33; IC 8-1-2-39

Sec. 17. Underset Radiation. Consumers having less than the proper amount of radiation installed shall be billed at the following increased rate until such time as they can procure and install the proper amount of radiation. Rates for direct radiation, where less than normal or standard amount of radiation is installed:

90% of normal or standard radiation installed, add 5% to normal rate.

80% of normal or standard radiation installed, add 10% to normal rate.

70% of normal or standard radiation installed, add 15% to normal rate.

60% of normal or standard radiation installed, add 20% to normal rate.

50% of normal or standard radiation installed, add 25% to normal rate.

Note.—By normal or standard amount of radiation is meant the radiator area required to keep the room or building at 70° F. inside when the outside temperature is zero in calm weather. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 17; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1662; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-18 Customer request for test; application to utility

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33; IC 8-1-2-37

Sec. 18. Test on Request of Consumer to Utility. (a) In case of complaint by a consumer alleging inadequate service, the utility shall immediately investigate the heating system on said consumer's premises, taking such measurements and data as may be necessary to disclose the difficulty. If the utility is at fault it shall remedy the trouble as soon as practicable. If the utility is not at fault it shall recommend to the consumer in writing what changes should be made to give the desired service.

(b) Evidence of the adequacy of service shall be that, with all radiator valves open and radiators free from sediment, the average temperature of the flow and return water, measured at or near the point of entrance of the service pipes to the building, shall not be less than the day schedule of temperature given in the table of average temperatures of flow and return.

(c) Evidence of the adequacy of the number of square feet of radiation set shall be that, with all the radiator valves open and radiators free from sediment, and the average temperature of the flow and return water maintained as given in table of average temperatures for the day schedule, making allowance for temperature-lowering effects of wind velocity, and with the outside openings, such as doors and windows, etc., properly closed and maintained so as to exclude the outside air in cold weather, and the utility furnishing at least six pounds of water per square foot of radiation, and with the pressure differential between flow and return pipe maintained to at least one-half pound per square inch working pressure and the inside building temperature maintained at 70 degrees Fahr., then and in that case the number of square feet of radiation shall be considered as adequate. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 18; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1663; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-19 Customer request for test; application to public service commission

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33

Sec. 19. Test or Inspection upon Application to the Commission. Upon formal application of any consumer to the commission, an inspection and if necessary, a test will be made upon the consumer's heating system, such inspection or test to be made as soon as is practicable after the receipt of the application. If the commission finds that the utility is at fault and has rendered inadequate service, the expense of the investigation or test shall be borne by the utility and the cause of inadequate service be remedied within

a period of time as determined by the commission. If the commission finds that the consumer is at fault, the expense of the investigation or test shall be borne by the consumer and the cause for inadequate service be remedied within a period of time as determined by the commission. In case a test is required a cash deposit of five dollars shall be made with the commission by the petitioner previous to the making of the test. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 19; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1664; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-20 Regulation of service; installation standards

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-33

Sec. 20. Regulation of Consumer's Service. (a) Each utility may regulate the water on the consumer's installation by thermostatic regulator, differential valve, or other device, and shall maintain such regulating device or devices at its own expense.

(b) Each utility shall, from time to time, give its consumers such information and assistance as is reasonably necessary, in order that the consumer may secure safe and adequate service from the heating installation.

(c) The heating installations of all consumers, including cast iron radiation, piping, and other heating devices, shall be thoroughly cleaned by the utility, at reasonable intervals of time as determined by the commission, of all corrosion, mud and other sediment.

(d) The utility may require, on old installations where there is complaint as to service, the consumer to install at his own expense suitable connections for a venturi tube, also thermometer wells and pressure gauge connections at the point where the service pipes enter the building, in order that the quantity of heat furnished the consumer by the utility during any given period of time may be measured.

(e) The utility shall by its inspectors, agents, or workmen, have the right of free access, at all reasonable hours, to the premises supplied with heat, to the valves, or service pipe from mains, to look after the heating system, to turn the water on or off, to adjust and care for the controlling devices or other portions of the heating system of said premises, and to make any and all such tests as may be necessary. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 20; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1664; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-21 Drawing-off of water; consent of utility

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-33; IC 8-1-2-38; IC 8-1-2-39

Sec. 21. Using or Draining Water from Heating System. The hot water supplied by the utility is the property of the utility and the drawing off of any of this water for any purpose shall not be permitted except upon written consent of the utility. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 21; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1665; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-22 Payment for heating service; recommended payment schedule

Authority: IC 8-1-1-3; IC 8-1-2-4
Affected: IC 8-1-2-33; IC 8-1-2-38; IC 8-1-2-39

Sec. 22. Payment for Heating Service. (a) All hot water heating service shall be furnished on a season basis and bills shall be payable monthly from October 1st to April 1st, inclusive. The per cent of the total heating bill that should be due per month of service shall be determined by the utility, subject to the approval of the commission and included as a part of the contract with the consumer.

The following payments for heating service are recommended:

October 1st	10 per cent.
November 1st	15 per cent.
December 1st	15 per cent.
January 1st	20 per cent.
February 1st	20 per cent.
March 1st	10 per cent.

April 1st 10 per cent.

(b) A consumer receiving service as per his request for a period less than the full heating season shall be charged one-half of the regular rate for that portion of the heating season in which service is not taken and at the full rate for that part of the season in which service is taken.

(c) All contracts for hot water heating service should be made in duplicate, one copy of which shall be given to the consumer and the other copy retained on file by the utility. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 22; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1665; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-23 Heating season defined

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33

Sec. 23. Heating Season. Each utility shall contract to maintain regular heating service from October 1st to April 30th, whenever the outside temperature is at a point below 60 degrees F., and at such other times after September 14th and before May 21st when the outside temperature is 60 degrees F., or below. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 23; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1666; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-24 Radiation requirements; temperature in consumer's premises

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-38; IC 8-1-2-39

Sec. 24. Radiation Requirements—Temperature in Consumer's Premises. Each utility shall contract to deliver hot water in sufficient quantities to maintain in the consumer's premises the agreed upon temperature when the outside temperature is zero degrees Fahr., provided, however, that doors, windows and ventilators are closed and tight and the premises are in evidence of good repair and that there is sufficient radiation set. (*Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 24; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1666; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-3-25 Estimate of required radiation; formula; table of factors

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-33

Sec. 25. Estimating Radiation Required. (a) As a tentative basis for the billing of contemplated new consumers and of such other consumers where there is complaint of inadequate service indicating insufficient radiation, each utility shall measure the buildings and premises of said consumers for radiation required by the formula and as set out in the table showing temperature-lowering coefficients of wind movements.

(b) Upon the request of any consumer, or the commission, the utility shall furnish a complete detailed set of figures and data relating to the radiation requirements, in said consumer's premises, upon which it is proposed that the consumer is to be billed for heating service.

(c) The utility supplying hot water heating service shall not be required to contract with any consumer to heat only a part of the used portion of a building, residence, or apartment where such other parts of the building or buildings are not provided with adequate radiation suitably connected.

Table Showing Formula for Estimating Radiation

$$R = C \times Fc + (E - W - D) \times Fe + (W \times Fw) + (D \times Fd)$$

- Where:
- R = Required radiation in square feet.
 - C = Cubic feet of contents.
 - E = Square feet of exposed walls.
 - W = Square feet of windows.

WATER UTILITIES

- D = Square feet of doors.
- Fc = Factor for cubic contents as shown in table.
- Fe = Factor for exposed walls, ceiling or floors as in table.
- Fw = Factor for windows as shown in table.
- Fd = Factor for doors as shown in table.

Table of Factors

Kind of Exposure	Difference in Temperature Between Room and Outside				
	60°	65°	70°	75°	80°
Fw					
Single glass	.478	.517	.557	.595	.705
Double or plate glass	.212	.229	.247	.265	.282
Single sky light	.382	.413	.445	.477	.508
Double sky light	.212	.229	.247	.265	.282
Fd					
Good door, one-half glass	.244	.265	.285	.305	.325
Good door, solid	.170	.184	.198	.212	.226
Fe					
Frame wall (N-W exposure)	.148	.160	.173	.185	.198
Frame wall (S-E exposure)	.134	.146	.159	.171	.184
12" masonry wall (N-W exposure)	.106	.115	.124	.132	.141
12" masonry wall (S-E exposure)	.093	.102	.111	.119	.128
17" masonry wall (N-W exposure)	.085	.092	.099	.106	.113
17" masonry wall (S-E exposure)	.071	.078	.085	.092	.099
Ceiling with no heat in space above	.106	.115	.124	.132	.141
Floor with no heat in space below	.053	.057	.062	.067	.071
Partition wall (frame plastered) but no heat on other side	.071	.077	.082	.088	.094
Cubic Contents					
Fc					
½ change of air per hour— Garages, etc.	.0032	.0035	.0038	.0040	.0043
1 change of air per hour— Dwellings, officers, etc.	.0064	.0069	.0075	.0080	.0086
2 changes of air per hour—Public assembly rooms	.0128	.0139	.0150	.0160	.0172

(Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 25; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1666; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-3-26 Rate schedules, rules and regulations; filing; public inspection

Authority: IC 8-1-1-3; IC 8-1-2-4

Affected: IC 8-1-2-13

Sec. 26. File of Rate Schedules, Rules, and Regulations of the Utility and of the Commission. (a) Copies of all schedules of rates for service, forms of contracts, charges for service connections and extensions of lines and of all rules and regulations covering the relations of consumers and utility shall be filed by each utility in the office of the commission. Complete schedules, contract forms, rules and regulations, etc., as filed with the commission, shall also be open to the inspection of the public.

(b) It is recommended that a copy of the rules and regulations for central station hot water heating service as published by the Public Service Commission should be on file and open to the inspection of the public.

(c) It is recommended that the attention of the public be called to these files of schedules, rules and regulations, by placing a suitable placard in the office of the utility. *(Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Sec 26; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1668; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

WATER UTILITIES

170 IAC 6-3-27 Station flow temperature table

Authority: IC 8-1-1-3; IC 8-1-2-4
 Affected: IC 8-1-2-13

Sec. 27. Table A.

TABLE A
 Station Flow Temperatures

Outside Temperature Degrees Fahrenheit	Day Schedule	Permissible Night Schedules	
	6:00 a.m. to 6:00 p.m.	6:00 p.m. to 9:30 p.m. 3:30 a.m. to 6:00 a.m.	9:30 pm. to 3:30 a.m.
70	85	90	75
65	97	103	87
60	109	115	99
55	120	125	110
50	130	135	120
45	139	144	129
40	148	152	139
35	156	160	148
30	164	167	158
25	171	174	167
20	178	179	176
15	185	185	185
10	190	190	190
5	195	195	195
zero	200	200	200
-5	203	203	203
-10	206	206	206
-15	208	208	208
-20	210	210	210

NOTE.—In case of difficulty in maintaining the average temperatures with these flow temperatures, increase the rate of pumpage.

(Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Table A; filed Jan 2, 1946, 10:00 am; Rules and Regs. 1947, p. 1669; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-3-28 Contract form

Authority: IC 8-1-1-3; IC 8-1-2-4
 Affected: IC 8-1-2-13

Sec. 28. (Standard Form of Central Station Hot Water Heating Contract recommended by the Public Service Commission of Indiana.)

Contract for Central Station Hot Water Heating.

THIS AGREEMENT entered into this ____ day of ____, 19____, by and between ____ Company, hereafter called "Company" and ____ hereinafter called "Consumer."

Witnesseth: For and in consideration of the mutual covenants and agreements hereinafter contained, the parties hereto agree with each other as follows:

The Company agrees to furnish to the Consumer during the term of this agreement, and the Consumer agrees to take from the Company, subject to the rules and regulations which are a part of the published Rate Schedule of the Company, and which are hereby incorporated in this agreement, hot water heating service in the premises located at ____.

The Company is to furnish and the Consumer is to take the heating service under the terms of this agreement, for a period of ____ year ____, beginning the ____ day of ____, 19____, and continuing thereafter in successive periods of not less than ____ year ____ each, until either party shall give the other not less than thirty (30) days' notice in writing of its or his election

WATER UTILITIES

to discontinue the service at the expiration of any such specified periods, provided, however, that no cancellation of this agreement shall be effective during any heating season.

The Consumer agrees to pay to the Company for such hot water heating service the sum of _____ (\$ _____) per year, payable as follows:

October 1st	10% of total specified above
November 1st	15% of total specified above
December 1st	15% of total specified above
January 1st	20% of total specified above
February 1st	20% of total specified above
March 1st	10% of total specified above
April 1st	10% of total specified above

which is at the rate of _____ cents per square foot of direct radiation and an increased rate of 100% for indirect radiation, plus a flat rate charge of _____ dollars per season for _____ gallons capacity of range boiler for domestic supply.

This service for range boilers does not apply to barber shops, public baths, laundries or other customers using large quantities of hot water, nor will such service in any event be rendered except during the regular heating season.

The regular heating season is understood to be from October 1st to April 30th inclusive when the outside temperature is at a point below 60° Fahr., and at such other times after September 14th and before May 21st when the outside temperature is 60° Fahr., or below.

It is further understood and agreed by the parties hereto that no range boiler or other apparatus for the heating of water shall be connected to the system without the written consent of the Company and when so connected shall be paid for at the regular heating rates of the Company.

Consumers connected to and receiving the hot water service after the beginning of the heating season shall be charged one-half of the rate for the expired portion of the heating season and at the full rate for the remainder of the season.

Consumers receiving service as per their request for a period less than the full heating season shall be charged one-half of the regular rate for that portion of the heating season in which service is not taken and at the full rate for the remainder of the season in which service is taken.

The premises to be heated under this contract are described in the accompanying diagram.

IT IS AGREED, That the Consumer shall equip and furnish the above described premises with an interior system of radiation, consisting of radiators, pipes and other apparatus and appliances for hot water heating, extending to the outside of the building to a point designated by the Company, the arrangement and material of said system and the workmanship thereon to be approved by the Company before any obligation on its part is incurred hereunder. All pipes and connections which are now or may hereafter be placed outside of the building on said premises, at the expense of the company, shall be and remain the property of the Company and subject to its exclusive control, and may be removed by it whenever this contract is terminated for any cause.

IT IS AGREED, That the Consumer shall keep the storm sash strips and protections to the doors and windows securely fastened in place and maintained so during the heating season. Failure by said Consumer to comply with this agreement shall work a forfeiture of this contract if the Company so elects.

The Company will at all times exercise reasonable diligence in supplying water in sufficient amount and of such a temperature, as will reasonably heat the premises of the Consumer, with all windows and other openings properly closed and maintained.

IT IS AGREED by the Company that it will furnish hot water in a sufficient quantity to heat said building to a temperature of not less than 70 degrees Fahr. when outside temperature is zero degrees Fahr., provided that sufficient radiation be installed by the Consumer to maintain the desired temperature. Evidence of the adequacy of service shall be that with all radiator valves open and radiators free from sediment the average temperature of the flow and return, measured at the entrance of the service pipe to the building, shall not be less than specified by the rules of the Public Service Commission of Indiana.

IT IS AGREED by the Consumer that he will not in any manner change, divert or use the water circulating through said interior system and through said connections or permit the same to be changed, diverted or used, and will exercise at all times reasonable care for the protection of the Company's property on the premises and will not install any additional radiation in said premises without the written consent of the Company endorsed herein, and that properly identified authorized agents and employees of the Company shall have the right to enter at reasonable hours upon the premises herein described for the purpose of inspecting said interior system and said connections; that the Consumer will at all times keep said interior system and that part of service line owned by him and the building in good repair and condition at his own expense, and the outside openings properly closed so as to exclude the outside air in cold weather during the heating season; and that it is expressly agreed that the Company shall not be liable for any failure of

WATER UTILITIES

circulation in said interior system nor for damage to person or property arising directly or indirectly from the furnishing of said heat on said premises, or for defects in said interior system. However, all controlling devices and shut-off valves shall be installed at the expense of the consumer and maintained at the expense of the Company.

IT IS AGREED by the Consumer that he will make all reasonable effort to prevent all persons other than the duly authorized representatives of the Company from making use of the shut-off cocks of the heating connections outside or inside of the building; that, when the circulation is once established and the water turned on, such service shall not be discontinued except by an authorized representative of the Company; that the Company may seal all drain valves between the heating system and the sewer; and in case drain valves are interfered with by any person such interference shall constitute a breach of this contract on the part of the Consumer.

It is understood that the water in the pipes and radiators is the property of said Company, and the drawing off of any of this water, for any purpose, shall be considered a violation of this contract and the Company shall have the right to and may collect from said Consumer the full value of the water and heat contained.

The Company reserves the right to refuse to contract for service with any person other than the owner of the building to be heated.

It is hereby agreed and understood that the Company shall not be liable for any damage to person or property caused by the lack of hot water sufficient to heat such premises, provided said lack of hot water be caused by accident, breakage or any other cause beyond the control of the Company, and that said Company shall not be liable for damage caused by leaks in the piping or radiation, caused by bursting pipes or otherwise.

The Company shall at reasonable hours by its inspectors, agents, or workmen properly identified have the right of free access to the premises supplied with heat, to the valves or service pipe from mains, to look after the heating system, to turn the water on or off, to adjust and care for the controlling devices or other portions of the heating system of said premises, and to make any and all such tests as may be necessary or desired by the Company.

The Consumer should notify the Company promptly of any defects in the service or any trouble or accident to the hot water supply.

A deposit satisfactory to the Company will be required from all consumers unable to give the Company a satisfactory reference. The Company will pay interest at the rate of 6% per annum on deposits so made.

It is also agreed that this contract is not assignable nor transferable by the Consumer without the written consent of the Company and that in case of a sale or leasing of said premises by the Consumer during the life of this contract no rights under this contract shall pass to the purchaser of such sale or lease, and in case of such sale or lease the Company or its successors or assigns may at its or their option cancel this contract and shut off the supply of heating service to said premises.

This contract is subject to all rules and regulations of the Public Service Commission of Indiana and of the Company as herein set forth and on file with the Public Service Commission of Indiana, duplicate copies of which are on file in the local office of the company and no promise, agreement, or representation of any agent or employee of the Company shall be valid unless incorporated in this contract.

Unless otherwise stated this contract is for one year only.

____ Consumer.

Accepted this ____ day of ____, 19____ Company.

By _____

By _____

(Indiana Utility Regulatory Commission; No. 17689: Standards of Service For Central Station Hot Water Heating Utilities Form; filed Jan 2, 1946, 10:00 am: Rules and Regs. 1947, p. 1669; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

Rule 4. Small Water Utilities; Rate Changes (Repealed)

(Repealed by Indiana Utility Regulatory Commission; filed Jun 28, 1991, 3:20 p.m.: 14 IR 1948)

Rule 5. Water Tracker Procedure

170 IAC 6-5-1 "Application for water tracker" defined

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47

Affected: IC 8-1-2-42; IC 8-1-2-125; IC 8-1-2.7

Sec. 1. As used in this rule, "application for water tracker" means an application submitted to the engineering division of the

commission in accordance with section 7 of this rule and IC 8-1-2-42, that functions as a request or in support of a request for a water tracker. (*Indiana Utility Regulatory Commission; 170 IAC 6-5-1; filed Dec 3, 1990, 9:34 a.m.: 14 IR 557; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-5-2 “Commission” defined

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 2. As used in this rule, “commission” refers to the Indiana utility regulatory commission. (*Indiana Utility Regulatory Commission; 170 IAC 6-5-2; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-5-3 “Supplier” defined

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 3. As used in this rule, “supplier” means a utility supplying water to a water utility. (*Indiana Utility Regulatory Commission; 170 IAC 6-5-3; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-5-4 “Water tracker” defined

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 4. As used in this rule, “water tracker” means the procedure available to a water utility under this rule to recover an increase or a decrease in costs associated with purchased water due to a change in the supplier's rates. (*Indiana Utility Regulatory Commission; 170 IAC 6-5-4; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-5-5 “Water tracker information form” defined

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 5. As used in this rule, “water tracker application form” means the forms, schedules, and instructions provided by the engineering division of the commission under this rule. The commission staff shall develop the forms, schedules, and instructions that comprise the water tracker application form and shall revise the water tracker application form as needed. (*Indiana Utility Regulatory Commission; 170 IAC 6-5-5; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-5-6 “Water utility” defined

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 6. As used in this rule, “water utility” means a utility supplying water service to the public at rates that are subject to the jurisdiction of the commission and that purchases water for ultimate resale to the public. (*Indiana Utility Regulatory Commission; 170 IAC 6-5-6; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233*)

170 IAC 6-5-7 Water tracker procedure

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 7. A water utility may apply to the commission to recover an increase or decrease in the costs associated with purchased water by submitting an application for water tracker to the engineering division of the commission. The application must include the following:

- (1) A completed water tracker application form. The form is available from the engineering division of the commission.
- (2) Proof of publication of notice in accordance with section 8 of this rule.
- (3) A copy of:
 - (A) the resolution or ordinance of the water utility's governing body authorizing the application for water tracker; or
 - (B) the minutes of the meeting of the water utility's governing body where the application for water tracker was authorized.
- (4) A verified statement by an officer or manager of the water utility in support of the proposed change in the utility's schedule of rates and charges that specifies the amount of the water tracker.
- (5) Two (2) unmarked copies of the water utility's current schedule of rates and charges incorporating the water tracker.

(Indiana Utility Regulatory Commission; 170 IAC 6-5-7; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-5-8 Publication of notice

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-42; IC 8-1-2-125; IC 8-1-2.7

Sec. 8. A water utility that files an application for water tracker shall publish notice of the filing at least twenty (20) days prior to the proposed effective date of the water tracker. Notice must be published in a newspaper of general circulation in all counties in which the water utility renders service. The notice must contain the following:

- (1) The amount of the water tracker to be applied to the water utility's schedule of rates.
- (2) A statement that the rate change is based solely on the change in the cost of water purchased by the water utility.
- (3) The name of the supplier.
- (4) A statement that the rate change will apply to the next practical consumption period following final approval by the commission in accordance with IC 8-1-2-42.

(Indiana Utility Regulatory Commission; 170 IAC 6-5-8; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-5-9 Application of water tracker

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 9. Once a water utility employs the water tracker procedure of this rule to recover an increase in the cost associated with purchased water, the utility must use the water tracker to offset its rates by any decrease the water utility experiences in the cost of purchased water. A water utility required to offset its rates by any decrease must make its application within thirty (30) days of the implementation of the decrease. *(Indiana Utility Regulatory Commission; 170 IAC 6-5-9; filed Dec 3, 1990, 9:34 a.m.: 14 IR 558; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)*

170 IAC 6-5-10 Commission review

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47
Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 10. The commission staff shall review each application for water tracker submitted to the commission. The review must include an investigation into the following:

- (1) Whether or not the revised purchased water costs are true and correct.
- (2) Whether or not the proposed revised rates filed by the water utility are equal to the actual increase or decrease in the purchased water expense.
- (3) Whether or not the water utility's calculations are mathematically accurate.
- (4) The effective date of the supplier's rates and the nature and permanency of those rates.

(Indiana Utility Regulatory Commission; 170 IAC 6-5-10; filed Dec 3, 1990, 9:34 a.m.: 14 IR 559; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

170 IAC 6-5-11 Commission action

Authority: IC 8-1-1-3; IC 8-1-2-42; IC 8-1-2-47

Affected: IC 8-1-2-125; IC 8-1-2.7

Sec. 11. (a) After conducting its review in accordance with section 10 of this rule, the commission staff shall report its recommendations in writing to the commission.

(b) After reviewing the staff's recommendations the commission may:

(1) approve the application;

(2) disapprove the application; or

(3) approve a modified version of the application.

(Indiana Utility Regulatory Commission; 170 IAC 6-5-11; filed Dec 3, 1990, 9:34 a.m.: 14 IR 559; readopted filed Jul 11, 2001, 4:30 p.m.: 24 IR 4233)

*