

**TITLE 675 FIRE PREVENTION AND BUILDING
SAFETY COMMISSION**

LSA Document #04-217(F)

DIGEST

Amends 675 IAC 18-1.4, the 2003 Indiana Mechanical Code, to make numerous substantive and clarifying changes. Effective 30 days after filing with the Secretary of State.

675 IAC 18-1.4-10.5 675 IAC 18-1.4-32.5
675 IAC 18-1.4-11.5 675 IAC 18-1.4-49.5
675 IAC 18-1.4-32.3

SECTION 1. 675 IAC 18-1.4-10.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-10.5 Section 304.3; elevation of ignition source
Authority: IC 22-13-2-2; IC 22-13-2-13
Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 10.5. In the second sentence of Section 304.3, Elevation of ignition source, before “Group”, delete “use”. (Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-10.5; filed Aug 30, 1:00 p.m.: 29 IR 11)

SECTION 2. 675 IAC 18-1.4-11.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-11.5 Section 310; explosion venting
Authority: IC 22-13-2-2; IC 22-13-2-13
Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 11.5. Change the title of Section 310 to read “Explosion Control”. (Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-11.5; filed Aug 30, 1:00 p.m.: 29 IR 11)

SECTION 3. 675 IAC 18-1.4-32.3 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-32.3 Section 607.5.4; corridors/smoke barriers
Authority: IC 22-13-2-2; IC 22-13-2-13
Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 32.3. Delete the text of Exception 2 in Section 607.5.4 and substitute “Smoke dampers shall not be required in duct penetration of smoke barriers in fully ducted heating, ventilating, and air conditioning systems.”. (Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-32.3; filed Aug 30, 1:00 p.m.: 29 IR 11)

SECTION 4. 675 IAC 18-1.4-32.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-32.5 Section 607.5.5.1; penetrations of shaft enclosures
Authority: IC 22-13-2-2; IC 22-13-2-13
Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 32.5. In the first sentence of Section 607.5.5.1, delete “and smoke” without substitution. (Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-32.5; filed Aug 30, 1:00 p.m.: 29 IR 11)

SECTION 5. 675 IAC 18-1.4-49.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-49.5 Section 1403.2; flammable gases and liquids

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 49.5. In the second sentence of Section 1403.2, delete “Use”. (*Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-49.5; filed Aug 30, 1:00 p.m.: 29 IR 11*)

LSA Document #04-217(F)

Notice of Intent Published: September 1, 2004; 27 IR 4047

Proposed Rule Published: January 1, 2005; 28 IR 1309

*Hearing Held: March 17, 2005, **AND** May 4, 2005*

Approved by Attorney General: August 23, 2005

Approved by Governor: August 30, 2005

Filed with Secretary of State: August 30, 2005, 1:00 p.m.

IC 4-22-7-5(c) Notice from Secretary of State Regarding Documents Incorporated by Reference: None Received by Publisher